



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: April 05, 2017	NO.: RFI-508
--------------------------------	-----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Circuit number for OR light

Response Required By: April 12, 2017

Drawing / Spec Reference:

Information Requested:

Please advise of the circuit number or panel for the OR light in SIM lab room 133.

Response:

Connect Sim Lab OR light to circuit 25. This circuit, which also serves a receptacle in the room, is being routed via the lighting contactor. This will ensure the contactor will turn off the OR Light in the event of a simulated power outage.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 4/11/17