



**PARIC CORPORATION**  
77 Westport Plaza Suite 250  
St. Louis, MO 63146  
TEL: 636-561-9500  
FAX: 636-561-9501

---

|                                |                             |                     |
|--------------------------------|-----------------------------|---------------------|
| <b>REQUEST FOR INFORMATION</b> | <b>DATE:</b> April 06, 2017 | <b>NO.:</b> RFI-510 |
|--------------------------------|-----------------------------|---------------------|

---

To: Cannon Design

---

Attn: Kelvin Patel

---

From: Paric Corporation

---

Requested By: Devin Gates

---

|                                                                           |                    |
|---------------------------------------------------------------------------|--------------------|
| Project Name: 15051-Webster University Interdisciplinary Science Building | Project No.: 15051 |
|---------------------------------------------------------------------------|--------------------|

---

Subject: Quantity of lights in C350 corridor

---

Response Required By: April 13, 2017

---

Drawing / Spec Reference:

---

**Information Requested:**

See attached screenshots. There is a discrepancy on layout and quantity of lights in corridor C350 between the architectural and electrical drawings. Please advise which drawing to utilize (the lights have been ordered per electrical drawings, so this is the preferred choice) and provide revised layout if electrical drawing is used.

**Response:** Functionally either layout works, but the electrical layout was the preferred layout. Our understanding is that the lights have already been installed per the architectural plans, with the exception of the Type RH downlight closest to the stairs. Do not install this last fixture as it would put two Type RH downlights right next to each other.  
In addition, there is a light fixture missing in the elevator lobby (outside of Data 300B) that will need to be installed and connected to switch leg "3d". See attached image of Corridor C370.

**ARCHITECT'S RESPONSE:**

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 4/13/17





