



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** April 14, 2017 **NO.:** RFI-518

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Wall clarification at stair 2

Response Required By: April 21, 2017

Drawing / Spec Reference:

Information Requested:

The stair plans on A0502 give a cut section of 6/A0502 which does not give much detail on the exterior wall assembly. A separate cut 4/A0457 which occurs between A.5 and A.6 shows a similar detail with a sheet on the inside face of the wall. Please confirm the interior layer of drywall will not be needed due to the L3 wall that will be built in front of it at the stair locations.

Response:

THAT IS CORRECT. PROVIDE INTERIOR LAYER OF GYPSUM BOARD PER EXTERIOR WALL ASSEMBLY AT LOCATIONS WHERE NO INTERIOR PARTITION IS PRESENT.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 04/19/2017