



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** April 26, 2017 **NO.:** RFI-525

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Lecture hall rail finish

Response Required By: May 03, 2017

Drawing / Spec Reference:

Information Requested:

RFI 280 identifies the lecture hall rails as type 1, spec section 057300.1.10 would have these powder coated. Please confirm if these should be powder coated (provide color) or prime painted similar to other interior steel rails.

Response:

Prime-Painted is acceptable in lieu of powder coating for these rails.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 04/27/2017