



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: May 04, 2017 NO.: RFI-527

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Acoustic Isolation Ceiling

Response Required By: May 11, 2017

Drawing / Spec Reference:

Information Requested:

Detail 14/A0842 shows a 1-1/2" 16 Ga. Continuous channel supporting the (2) layers of drywall. After speaking to the framing manufacturer, they do not manufacture this member. They do manufacture a 1-1/2" 18 Ga. Member. Please confirm if this is an acceptable solution.

Response:

Please use 16 ga cold rolled channel as specified - below is one manufacturer. This is part of the acoustic isolation system and is a standard component of gyp drop ceilings.

<http://www.clarkdietrich.com/products/bridging-bracing/u-channel-crc>

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 05.05.17