



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 04, 2017 **NO.:** RFI-528

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: East side site wall clarifications

Response Required By: May 11, 2017

Drawing / Spec Reference:

Information Requested:

3/A0505 shows the site wall that is 9'-9" from 8 line 1'-6" thick and the handrail on the inside edge. A0101.A shows the site wall 1'-0" thick and the handrail on the outside edge. E3/RSE002 on approved shops 033000-030 shows the wall 12" and the rebar has been fabricated accordingly.

Please confirm 12" will be acceptable and identify the desired handrail location within the wall.

Response:

Walls to be 12" thick.
Location of railings per A0505.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: **Kelvin Patel**
Jill Walker

Date: **05/12/2017**