



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** May 04, 2017 **NO.:** RFI-529

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Powder coated handrail

Response Required By: May 11, 2017

Drawing / Spec Reference:

Information Requested:

The contractor who will be using the Tiger-shield powder coating has requested the required gloss level for the tiger-shield 38 finish coat. They state that 30% is the lowest you would want to go for an exterior product.

They have also asked if they can provide 4 of the closest color chips to Sherwin Williams SW7075 (per RFI 420) for review. This would not be a cost savings but a schedule improvement.

Response:

Provide samples for gloss levels 30% and higher and also lower than 30%.
Are all the gloss levels available for any selected color? or there are limitations?

We can review at the 4 of the closest color chips to SW707 and decided if they are acceptable.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 05/05/2017