



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: May 10, 2017	NO.: RFI-537
--------------------------------	---------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Rack to ladder distance

Response Required By: May 17, 2017

Drawing / Spec Reference:

Information Requested:

27100-001states to provide necessary supports to mount cable runway approx. 20" above racks. The chatsworth system only goes up to 12". Please advise if this will be acceptable or provide an alternate part number.

Tom Becker has reviewed via email and requested the formal RFI.

Response:

THE 12" CABLE RUNWAY SUPPORTS ARE ACCEPTABLE.

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Tom Becker, Faith Group

Date: 5/15/17