



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: May 19, 2017	NO.: RFI-545
--------------------------------	---------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Power for Security Cabinet in Elevator Room

Response Required By: May 26, 2017

Drawing / Spec Reference:

Information Requested:

Please provide both a location of the security cabinet, location and power requirements, and the panel this should be fed from.

Response:

Locate the elevator security panel on the east wall of Data 100B, adjacent to the security panel previously installed. Connect to the same power circuit as the adjacent security panel. Maintain a minimum of 30" x 30" wall space for the TTB punchdown blocks between the elevator security panel and the north wall.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: _____

Date: _____