



**PARIC CORPORATION**  
77 Westport Plaza Suite 250  
St. Louis, MO 63146  
TEL: 636-561-9500  
FAX: 636-561-9501

---

|                                |                            |                     |
|--------------------------------|----------------------------|---------------------|
| <b>REQUEST FOR INFORMATION</b> | <b>DATE:</b> June 01, 2017 | <b>NO.:</b> RFI-553 |
|--------------------------------|----------------------------|---------------------|

---

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

|                                                                           |                    |
|---------------------------------------------------------------------------|--------------------|
| Project Name: 15051-Webster University Interdisciplinary Science Building | Project No.: 15051 |
|---------------------------------------------------------------------------|--------------------|

Subject: Striking joints at east screen wall

Response Required By: June 08, 2017

Drawing / Spec Reference:

**Information Requested:**

We are building a "mockup panel" for the east screen wall today. The existing wall has recessed, squared off joints, however these joints are known for catching moisture and deteriorating. The mason recommends a rounded tooled joint, please advise if we should match existing or provide the rounded tooled joint (recommended).

**Response:**

Per masonry mockup for review, provide mortar joints (raked) to match existing wall.

**ARCHITECT'S RESPONSE:**

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By:                     Kelvin Patel                    

Date:                     06/14/2017