



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: June 02, 2017	NO.: RFI-554
--------------------------------	----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Additional Data Drops Needed in 100B

Response Required By: June 09, 2017

Drawing / Spec Reference:

Information Requested:

We would like to request for 2 additional drops for 2 additional controllers. These controllers are needed to allow all the interface programs to work optimally with the HVAC system. One controller will encompass all the Phoenix interface programming and the other controller will encompass all the lighting interface program. These drops will be needed in Room 100B.

Response:

WE FIND THIS REQUEST ACCEPTABLE.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Tom Becker, Faith Group

Date: 6/7/17