



**PARIC CORPORATION**  
77 Westport Plaza Suite 250  
St. Louis, MO 63146  
TEL: 636-561-9500  
FAX: 636-561-9501

---

|                                |                            |                     |
|--------------------------------|----------------------------|---------------------|
| <b>REQUEST FOR INFORMATION</b> | <b>DATE:</b> June 06, 2017 | <b>NO.:</b> RFI-556 |
|--------------------------------|----------------------------|---------------------|

---

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

|               |                                                             |                    |
|---------------|-------------------------------------------------------------|--------------------|
| Project Name: | 15051-Webster University Interdisciplinary Science Building | Project No.: 15051 |
|---------------|-------------------------------------------------------------|--------------------|

Subject: Fume Hood Grounding

Response Required By: June 13, 2017

Drawing / Spec Reference:

**Information Requested:**

The fume hoods have a decal stating "metal fume hood superstructure must be connected to building ground to comply with UL 1805 certification" (see attached photo). Please advise if these need to be grounded and include additional information if necessary.

**Response:** Per specification section 115313, provide UL 1805 listed hood. Equipment to be connected as indicated by manufacturer's instructions. Per drawing Keyed Note E16, "Provide power and final connections to fume hood." We recommend connecting the ground wire to the grounding terminal as required by the manufacturer in order to maintain the UL listing.

**ARCHITECT'S RESPONSE:**

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 6/7/17

# WARNING!

METAL FUME HOOD  
SUPERSTRUCTURE MUST BE  
CONNECTED TO BUILDING  
GROUND TO COMPLY WITH  
UL 1805 CERTIFICATION



GROUND WIRE

