



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** June 08, 2017 **NO.:** RFI-560

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Confirm Sealant Color for Coping to Masonry

Response Required By: June 15, 2017

Drawing / Spec Reference:

Information Requested:

Please confirm the sealant color from the coping to masonry should match the mockup. See attached.

Response:

Color of sealant between masonry and coping should match the masonry mortar color.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 06/15/2017

