



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 08, 2017 NO.: RFI-561

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Flammable/Acid Storage Cabinets Venting

Response Required By: June 15, 2017

Drawing / Spec Reference:

Information Requested:

Please verify if the acid and flammable storage cabinets in room 289A, north elevation are to be ventilated. There are vent ports on the backside of the cabinets to allow venting. If venting is required please provide details. City of St. Louis typically requires cabinets to be hard piped (stainless steel) to the exhaust ductwork.

Response:

Confirm with AHJ and Webster University if ventilation is required.

NFPA-30-9.5.4 indicates that storage cabinets are not required to be ventilated for fire protection services. Also refer to NFPA 30-9.5.4.1 and NFPA 30-9.5.4.2 for additional information.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mike Nolte and Kelvin Patel

Date: 06.19.17