



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** June 14, 2017 **NO.:** RFI-564

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Plumbing vs. Architectural Clarifications

Response Required By: June 21, 2017

Drawing / Spec Reference:

Information Requested:

A0204 calls for a drench hose in room 291, this is not identified in the Plumbing drawings, please identify how this should be piped. Paric proposes to connect outside of the wall under the sink in the cabinet.

A0205 calls for an eye wash in room 386, this is not identified in the plumbing drawings, please identify how this should be piped. Paric proposes to connect outside of the wall under the sink in the cabinet.

Response:

Item 1: Lab 289 - The drench hose is unrelated to emergency eyewash/shower system. After reviewing on site and discussion with Kelvin Patel, this date, the drench hose can be connected to the domestic cold water under the sink. Provide a shut-off valve and spring loaded check valve. This also applies to Lab 391.

Item 2: Lab 386 - Provide eyewash as called for.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By:

Mike Whitworth - WES

Date:

June 15, 2017