



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 23, 2017 NO.: RFI-571

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Removable Back Panels at Dilution Tank

Response Required By: June 30, 2017

Drawing / Spec Reference:

Information Requested:

The lab drench hoses will be installed in the service space per discussion with Mike Whitworth and RFI 564. Once installed, these back panels will not be removable without the removal of the dilution tank. Please confirm if this is acceptable.

Response:

As discussed in OAC meeting (06/27/17), since the acid neutralization tanks can be removed, this is acceptable.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 06/28/2017