



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** June 23, 2017 **NO.:** RFI-572

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Black Gum Trees

Response Required By: June 30, 2017

Drawing / Spec Reference:

Information Requested:

The nursery has confirmed that the black gum trees for this project have failed. The landscaping contractor can either use another species (SWT to advise) or they can be installed in the fall (Webster and design team to confirm if acceptable). Please advise.

Response:

Due to constrained access after construction, substitution of the 3 black gum at Rain Garden 2 would be acceptable. Taxodium distichum `Shawnee Brave` is preferable.

The 4 black gum located at Rain Garden 1 along lot K are still desired. Planting these 4 in the fall planting season is acceptable.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Zach Snovelle

Date: 6/29/2017