



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** June 27, 2017 **NO.:** RFI-573

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: ASI #70 Light Bollard Relocation

Response Required By: July 04, 2017

Drawing / Spec Reference:

Information Requested:

Please advise of revised location for light bollard located in the bank of the revised rain garden.

Response:

Coordinate location with Civil Engineer. The design intent is to shift the bollard north while keeping it between the adjacent building exit doors.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 7/03/17