



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 27, 2017 NO.: RFI-575

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Power Requirements for Surgical Scrub Sinks

Response Required By: July 04, 2017

Drawing / Spec Reference:

Information Requested:

Power is required for the surgical scrub sinks, however not shown on the electrical drawings. Please provide power requirements.

Response:

Per owner direction, provide power for surgical scrub sinks in-lieu of utilizing battery power option. Per scrub sink documentation (page 78/425), provide outlet approximately 20" AFF. In Cadaver Lab 191, provide 20A GFCI duplex receptacle, and connect to adjacent circuit 13. In Sim Lab 133B, provide 20A GFCI duplex receptacle, and connect to circuit 27.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 7/03/17