



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 30, 2017 NO.: RFI-580

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Architectural Base at Columns

Response Required By: July 07, 2017

Drawing / Spec Reference:

Information Requested:

The base being used around the columns will not stay secured. The contractor feels this is due to the thickness of the material and proposes to use a thinner base material instead. They have tried multiple adhesives and securing methods but feel these will be an ongoing maintenance issue if installed per plan. Please advise if an alternate material may be utilized.

Response:

Use following base at the column covers -
Johnsonite Traditional Toeless Wall Base, 4", CBT.
Color Dover to match RB-1 & RB-2.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Amanda Renshaw

Date: 7/6/2017

