



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: July 06, 2017 NO.: RFI-584

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Wiremold Conflicts with Tables in Rooms 283 and 291

Response Required By: July 13, 2017

Drawing / Spec Reference:

Information Requested:

Due to the height of the tables on the west side of rooms 283 and 291, the wiremold cannot be installed as shown in 11/A0604. The height of the table leaves us little to no room to secure the wiremold. We suggest installing the wiremold on top of the window sill. Please advise if this would be acceptable.

Response:

Install the wiremold on top of window sill is acceptable and mount on mullion similar to upper levels.
Extend wiremold up to the next vertical mullion.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 07/10/2017