



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: July 10, 2017	NO.: RFI-588
--------------------------------	----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Twist locks at OHSC

Response Required By: July 17, 2017

Drawing / Spec Reference:

Information Requested:

The UB4 fixtures that plug into the OHSC will not work with the current twist lock plug scenario. The solution would be to change out the dual twist lock receptacle that feeds the lab under cabinet lights to a standard duplex receptacle. Please advise if this is acceptable.

Response:

The lighting manufacturer is providing a twist lock adapter to allow their fixture to connect to the overhead carrier as currently configured.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 07/03/2017