



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: July 17, 2017 NO.: RFI-589

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Ryan Tune

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Kitchen Hood Control Panel Location

Response Required By: July 24, 2017

Drawing / Spec Reference:

Information Requested:

The kitchen hood has a control panel for which the info can be found at the following link;
<https://www.captiveaire.com/CatalogContent/ElectricControls/Electrical.asp>

Please advise where this should be installed in the teaching kitchen.

Response:

As discussed on site, in conjunction with Captive Aire representative, locate control panel adjacent to Fire extinguisher cabinet.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 08/11/2017



WARNING: ELECTRICAL SHOCK HAZARD. DO NOT TOUCH THE ELECTRICAL COMPONENTS OF THE UNIT. ALWAYS USE PROPER SAFETY PROCEDURES WHEN WORKING WITH ELECTRICAL EQUIPMENT. FOR MORE INFORMATION, SEE THE USER MANUAL. THE INFORMATION ON THIS LABEL IS SUBJECT TO CHANGE WITHOUT NOTICE. © 2010 [illegible]