



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: July 20, 2017	NO.: RFI-594
--------------------------------	----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Wall covering clarifications

Response Required By: July 27, 2017

Drawing / Spec Reference:

Information Requested:

We are asking for clarifications of the following wall covering items;

Per the architectural drawings the east wall of rm 131 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the east wall of rm 135 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE PAINT AWC-1.**

Per the architectural drawings the west wall of rm 284 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the west wall of rm 276 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the east wall of rm 291 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the east wall of rm 283 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the south wall of rm 231 is shown as a writeable and projectable surface, per the finish schedule this is to be an AWC-1. Please advise which drawing to follow. **PROVIDE WRITEABLE PAINT AWC-1.**

Per the architectural drawings the south wall of rm 233 is shown as a writeable and projectable surface, per the finish schedule this is to be an AWC-1. Please advise which drawing to follow. **PROVIDE WRITEABLE PAINT AWC-1.**

Answered By: _____

Date: _____



Per the architectural drawings the west wall of rm 388 is shown as a writeable and projectable surface, per the finish schedule this is to be an PT-1. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the west wall of rm 378 is shown as a writeable and projectable surface, per the finish schedule this is to be an PT-1. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the east wall of rm 383 is shown as a writeable and projectable surface, per the finish schedule this is to be an PT-1. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the east wall of rm 391 is shown as a writeable and projectable surface, per the finish schedule this is to be an PT-1. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the east wall of rm 353 is shown as a writeable and projectable surface, per the finish schedule this is to be an AWC-1. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the west wall of rm 352 is shown as a writeable and projectable surface, per the finish schedule this is to be an PT-1. Please advise which drawing to follow. Please confirm the east wall of rm 352 as AWC-1 per the finish schedule. **PROVIDE WRITEABLE PAINT AWC-1.**

Per the architectural drawings the west wall of rm 488 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the west wall of rm 480 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the west wall of rm 472 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the east wall of rm 491 is shown as a writeable and projectable surface, per the finish schedule this is to be a PT-1 wall. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Per the architectural drawings the east wall of rm 483 is shown as a writeable and projectable surface, per the finish schedule this is to be an AWC-1. Please advise which drawing to follow. **PROVIDE WRITEABLE & PROJECTABLE SURFACE.**

Response:

ADDITIONALLY, CONFIRMING WRITEABLE PAINT AWC-1 AT ROOMS - 174, 303, 419, 441 AND LAB CORRIDORS PER INTERIOR (IDxxx) DRAWINGS.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 07/20/2017