PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION

DATE: August 01, 2017 **NO.:** RFI-599

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Data outlet in dry skills lab

Response Required By: August 08, 2017

Drawing / Spec Reference:

Information Requested:

A0201 indicates a D-6 data outlet on table apron of the mobile table with sim mannequin storage for demonstration. The technology drawings do not indicate any work on the table, only the floor box. The table has been supplied with a blank box for data and was flagged as incomplete work on the punchlist. Please advise if a cover plate should be installed on the table box and the data at the floor box utilized, or if a data jack needs to be installed in the apron. If an additional data drop is required please advise how it is to be configured. See attached photo.

Response:

Provide data outlets per A0201 on the table. The table should have a detachable data whip which will connect to the data outlet in floor box to activate data outlets on the table.

.

ARCHITECT'S RESPONSE:
This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel Date: 08/08/2017