



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: September 26, 2016 NO.: RFI-296

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Imbed Clarification on S0103

Response Required By: October 03, 2016

Drawing / Spec Reference:

Information Requested:

On Drawing S0103, along column line 4.6 there is a 8" step down in the foundation wall. At this location (between Column line Z and A.5 along column line 4.6) there is a 20" wide x 37" tall embed plate required to be installed. If the embed plate is centered for the steel beam that is to attach to it, the back of the embed plate will be exposed out of the concrete wall by 2".

Please advise if this is acceptable

Response:

**SHIFT THE EMBED PLATE 3" NORTH AND SET
THE W24 OFF CENTER OF THE PLATE.**

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: **JILL WALKER / DMA**

Date: **9/27/2016**