

From: Amanda Renshaw
To: [Patel, Kelvin](#)
Cc: [Grossman, Lynn](#); [Trisha Militello](#)
Subject: RE: Webster ISB - RFI 336
Date: Tuesday, October 25, 2016 11:01:16 AM
Attachments: [image002.png](#)
[image003.png](#)

Kelvin,

The instructor station will be mobile. It has been discussed that the instructor will have flexibility in placement, and would only plug into a wall/floor outlet as needed. All technology would be wireless, we would only need power. I would keep the floor outlet as shown on the current construction docs.

Thanks,

Amanda Renshaw
Designer
Spellman Brady & Company
8251 Maryland Avenue, Suite 300 | St. Louis, MO 63105
D 314-669-3471 | T 314-862-0070 x114
www.spellmanbrady.com
[Facebook](#) | [LinkedIn](#)


From: Patel, Kelvin [mailto:kpatel@CANNONDESIGN.COM]
Sent: Monday, October 24, 2016 6:22 PM
To: Amanda Renshaw; Trisha Militello
Cc: Grossman, Lynn
Subject: FW: Webster ISB - RFI 336

Amanda & Trisha,

Please review the RFI & let us know which furniture layout to follow.

Architectural drawings show teaching station at the end of tables while the furniture plans show at the north.

The floor box location needs to be based on teaching station location.



Thanks,

..

Kelvin Patel, CDT, LEED AP BD+C
Associate



T 314.425.8756

From: STL-CAC
Sent: Monday, October 24, 2016 2:16 PM

To: 'Patrick Garner' <pgarner@wmtao.com>; Tracie Grimm <tgrimm@wmtao.com>
Cc: Patel, Kelvin <kpatel@CANNONDESIGN.COM>
Subject: Webster ISB - RFI 336

Attached for review.

Melissa Pirtle



1100 Clark Ave
St. Louis, Missouri 63102
T 314.425.8797
cannondesign.com