

Inspection Requirements

Job No.: 391073

Date: July 6, 2017

System Owner: Webster University ISB

Type of System: Preaction

NFPA Standards: **72**

Manufacturer: Viking

State Code:

Type of Control Panel: VFR-400

System Component	Weekly	Monthly	Quarterly	Semi Annual	Annual	Other
Control Panel(s):						
Control Panel(s)					T	
Function					T	
Fuses					T	
Interfaced Equipment (Dialer)					T	
Lamps, LEDs					T	
Power Supplies					T	
Battery Charger					T	
2 Hour Battery Test					T	
Battery Load Voltage Test					T	
Battery Replacement						4 to 5 yrs.
Devices:						
Smoke Detectors				V	T	
Heat Detectors				V	T	
Pull Stations				V	T	
Abort Stations				V	T	
Horns and Strobes				V	T	
Alarm Switches				T		
Solenoids					T	
Supervisory Switches			T			
Tamper Switches				T		
Note: If system is not connected to a supervising station, control panel function tests are required quarterly. T = Test V = Visual Inspection (by owner)						