



Certificate of Compliance

as a

DESIGNATED RESPONSIBLE INDIVIDUAL

Is hereby granted on this day October 16, 2015 to:

Tom Riley
Firestoppers LLC

for successfully meeting all test criteria.

FM Approvals hereby certifies that the individual shown above met all test criteria contained in Approval Standard 4991, Approval of Firestop Contractors, to qualify as a Designated Responsible Individual (DRI).

Said recognition is subject to satisfactory field performance, accumulation of Continuing Education Units and periodic written re-examinations.

A handwritten signature in dark ink, appearing to read 'Cynthia Frank'.

Cynthia Frank, Assistant Vice President
Group Manager
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

Expires December 31, 2018

Shop Drawing Submittal Review

Transmitted To: Cannon Design

Date: April 24, 2017

Attention: stl-cac@cannondesign.com

Contact Person / WTA Field Inspector:
Patrick Garner

Project Name: Webster University-**ISB**

Reviewed by: Mark de la Fuente

Project No. WT 14127.01

☐

UPS

☐

Courier

☒

Email

Copies	No.	Description
1 PDF	078413 A01	(Submittal No. 07 8413-004)
		(Cannon #00000-004) - (Paric #15051-) – (WES #607)
		➤ Penetration Fire Stopping Product Data for
		Electrical Penetrations

Remarks: Per Specification Section 260500, Hilti is an approved manufacturer. Install per manufacturer's instructions to maintain fire rating of penetrated walls.

c: **Kelvin Patel**
Kpatel@cannondesign.com

☐

Furnish as Submitted

☐

Furnish as Noted

☐

Rejected

☐

Revise & Resubmit

☒

Reviewed

☐

Corrections or comments made on shop drawings during this review do not relieve contractor from compliance with requirements of drawings and specifications. This check is only for review of general conformance with the design concept of project and general compliance with information given in contract documents. Contractor is responsible for: confirming and correlating all quantities and dimensions; selecting fabrication processes and techniques of construction; coordinating his work with that of all other trades; and performing his work in a safe and satisfactory manner.

To be completed by Contractor/CM

DATE

DATE _____



77 Westport Plaza
Suite 250
St. Louis, MO 63146

TRANSMITTAL

No. 15051-0558

Paric Corporation

PROJECT: 15051-Webster University Interdisciplinary Science Building

DATE: 04/19/2017

TO: Cannon Design
1100 Clark Ave
St Louis MO 63102

Fax;
314-241-2203

RE: Penetration Firestopping Product Data For
Electrical Penetra

ATTN: Kelvin Patel

JOB: 15051

WE ARE SENDING:	SUBMITTED FOR:	ACTION TAKEN:
☐ Shop Drawings	☒ Approval	☐ Approved as Submitted
☐ Letter	☐ Your Use	☐ Approved as Noted
☐ Prints	☐ As Requested	☐ Returned After Loan
☐ Change Order	☐ Review and Comment	☐ Resubmit
☐ Plans		☐ Submit
☐ Samples	SENT VIA:	☐ Returned
☐ Specifications	☐ Attached	☐ Returned for Corrections
☒ Other: Product Data	☐ Separate Cover Via:	☐ Due Date:

Item	Package	Code	Rev.	Copies	Date	Description	Status
Submittal		078413-004	1		04/19/2017	Penetration Firestopping Product Data For Electrical Penetrations	Submitted

NOTES:

CC:

Signed: _____
Devin Gates