Webster - ISB **Issue List**

Issue ID	Description	Location Detail	Location	Status	Company	Type	Date Created	Due Date
001912	Seal the joint between CMU walls and concrete walls at all necessary locations		Webster > LEVEL_00	Open	<not set>	Architect Punch List	20 Jul 2017	25 Jul 2017
001915	Seal around door frame and CMU wall		Webster > LEVEL_00	Open	<not set>	Architect Punch List	20 Jul 2017	25 Jul 2017
001913	Seal all wall penetrations and holes in concrete wall		Webster > LEVEL_00	Open	ICON Mechanical	Architect Punch List	20 Jul 2017	25 Jul 2017
001917	Seal shaft with fire rated sealant		Webster > LEVEL_00	Open	ICON Mechanical	Architect Punch List	20 Jul 2017	25 Jul 2017
001916	Fire rated wall partition		Webster > LEVEL_00	Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001914	Paint exposed steel		Webster > LEVEL_00	Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017