Webster - ISB **Issue List**

Webster > LEVEL_01 (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001860	Seal concrete floor where necessary		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 100C_K'ETTE (8 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001662	Fix base so that cabinet doors and pocket doors are operable		Open	Flooring Systems, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017
001663	Fix holes in grout		Open	Flooring Systems, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017
001660	Repair drywall		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001661	Seal countertops to walls		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001664	Install cabinet doors		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001666	Cover needed to hide interior components of pocket door, possibly break metal		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001659	Repaint entire kitchen area/ add cork board and writeable paint surface		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001665	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 101_OFF. STAFF (2) (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001667	Remove plastic from lights		Open	Guarantee Electric	Architect Punch List	19 Jul 2017	24 Jul 2017
001669	Damaged door		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001670	Finish wall coverings		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001668	Replace missing ceiling tile		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 105_OFF. NA (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001672	Remove material from framing		Open	<not set>	Architect Punch List	19 Jul 2017	24 Jul 2017
001671	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 106_OFF. NA (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001673	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001674	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 107_OFF. NU (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001680	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001677	Adjust diffuser to sit flush		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 108_OFF. NU (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001675	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001676	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 109_OFF. NU (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001682	Remove marks from diffuser		Open	ICON Mechanical	Architect Punch List	19 Jul 2017	24 Jul 2017
001679	Damaged door		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001678	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001681	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 110B_ELEC (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001687	Seal penetration		Open	Guarantee Electric	Architect Punch List	19 Jul 2017	24 Jul 2017
001686	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 111_OFF. NU (8 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001694	Damaged door		Open	<not set>	Architect Punch List	19 Jul 2017	24 Jul 2017
001693	Scuffs on aluminum framing		Open	National Glass & Glazing, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017
001683	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001685	Remove paint from carpet		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001692	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001684	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017
001691	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017
001695	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 112_STORAGE (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001688	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001689	Replace damaged ceiling tile		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001690	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 113_OFF. NU (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001708	Gaps in covers too large		Open	National Glass & Glazing, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017
001696	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 114_MOCK EXAM (5 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001697	Seal countertops to wall		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001698	Adjust cabinet doors to be flush		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001699	Computer mounting arm and coat hooks missing (shipping end of month)		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001701	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001700	Replace damaged ceiling tile		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 115_OFF. NU (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001707	Gaps in covers too large		Open	National Glass & Glazing, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 116_MOCK EXAM (5 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001702	Handle mounted incorrectly		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001706	Damaged door		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001704	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001703	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017
001705	Clean inside of cabinet		Open	Titan Contractor Services	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 117_OFF. FUT (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001709	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001710	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 133A_CONTROL ROOM / TECH OFF / PREP LAB (10 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001732	Install grommets in countertops		Open	Carroll Seating	Architect Punch List	19 Jul 2017	24 Jul 2017
001733	Missing latch		Open	Carroll Seating	Architect Punch List	19 Jul 2017	24 Jul 2017
001734	Screws exposed on shelf		Open	Carroll Seating	Architect Punch List	19 Jul 2017	24 Jul 2017
001729	Lower raceway to top of backsplash (creating dust pocket), backer rod and sealant needed at void		Open	Guarantee Electric	Architect Punch List	19 Jul 2017	24 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001738	Remove decals from doors		Open	National Glass & Glazing, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017
001731	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001735	Walltalker needed on east wall		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001737	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001730	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017
001736	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 133B_SIM LAB (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001711	Missing trench covers		Open	Atlas Iron Works	Architect Punch List	19 Jul 2017	24 Jul 2017
001713	Adjust sensitivity of auto sensor on sink		Open	Deluca Plumbing	Architect Punch List	19 Jul 2017	24 Jul 2017
001714	Missing door silencers		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001712	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 135_DRY SKILLS LAB / COHORT CLASSROOM (7 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001716	Ensure pull out drawer is installed at all locations (missing in multiple)		Open	Carroll Seating	Architect Punch List	19 Jul 2017	24 Jul 2017
001717	Scratches and marks on casework		Open	Carroll Seating	Architect Punch List	19 Jul 2017	24 Jul 2017
001721	Mobile cabinet missing clips for shelf		Open	Carroll Seating	Architect Punch List	19 Jul 2017	24 Jul 2017
001720	Backer rod and sealant needed		Open	National Glass & Glazing, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017
001715	Need to seal between ceiling grid and wall in entire room		Open	Paric Corp.	Architect Punch List	19 Jul 2017	24 Jul 2017
001719	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001718	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 137_MODELS/ ASSESSMENT STORAGE/RESEARCH (7 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001724	Sprinkler head to be secured in cabinets		Open	Ahern Fire Protection	Architect Punch List	19 Jul 2017	24 Jul 2017
001722	All cabinet shelves to be adjusted so they do not wiggle		Open	Carroll Seating	Architect Punch List	19 Jul 2017	24 Jul 2017
001723	Missing filler panel		Open	Carroll Seating	Architect Punch List	19 Jul 2017	24 Jul 2017
001725	Flaw in face of cabinet		Open	Carroll Seating	Architect Punch List	19 Jul 2017	24 Jul 2017
001727	Repaint walls as needed		Open	Spectra Painting	Architect Punch List	19 Jul 2017	24 Jul 2017
001726	Repair ceiling components as needed -		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017
001728	General cleanup needed in room		Open	Titan Contractor Services	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 144_OFF. NU / NA ADJ. (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001851	Repair aluminum trim		Open	National Glass & Glazing, Inc.	Architect Punch List	20 Jul 2017	25 Jul 2017
001849	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 152_VENDING (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001845	Wood panel is not flush		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 154_CONF ROOM (10) (11 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001837	Repair carpet		Open	Flooring Systems, Inc.	Architect Punch List	20 Jul 2017	25 Jul 2017
001835	Repair aluminum trim		Open	National Glass & Glazing, Inc.	Architect Punch List	20 Jul 2017	25 Jul 2017
001832	Seal countertop to wall		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001833	Repair touch latches		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001840	Top on entry not finished		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001831	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001838	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001830	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017
001839	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017
001834	Clean base and floor		Open	Titan Contractor Services	Architect Punch List	20 Jul 2017	25 Jul 2017
001836	Clean carpet		Open	Titan Contractor Services	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 156_SM MTG/ GREEN RM (7 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001824	Gap in aluminum trim		Open	National Glass & Glazing, Inc.	Architect Punch List	20 Jul 2017	25 Jul 2017
001825	Repair aluminum trim		Open	National Glass & Glazing, Inc.	Architect Punch List	20 Jul 2017	25 Jul 2017
001826	Missing silicon at store front windows		Open	National Glass & Glazing, Inc.	Architect Punch List	20 Jul 2017	25 Jul 2017
001821	Damaged door frames		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001850	Missing screws		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001822	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001823	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 158_COAT (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001828	Top of entry not finished		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001827	Shelf supports not finished		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001829	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 160_LECTURE HALL (15 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001747	Threshold needed		Open	Flooring Systems, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001751	Flooring needed at stage, stairs, and sloped wall		Open	Flooring Systems, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017
001742	Lights need to be straight (in line with ceilings)		Open	Guarantee Electric	Architect Punch List	19 Jul 2017	24 Jul 2017
001819	Lights to align to west edge of ceiling to eliminate gap		Open	Guarantee Electric	Architect Punch List	20 Jul 2017	25 Jul 2017
001753	Install window		Open	National Glass & Glazing, Inc.	Architect Punch List	19 Jul 2017	24 Jul 2017
001740	Wall built incorrectly, should be fire rated per arch detail		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001745	Screws needed in exterior door jamb		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001746	No light should be visible when door is closed		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001748	Base at grills to be corrected per observation report 14		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001750	Subwoofer fabric needed		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001752	Install wall panel (cut to fit below equipment)		Open	PARIC (Self-Perform)	Architect Punch List	19 Jul 2017	24 Jul 2017
001741	Closer panel needed to fill voids between lights and ceiling - scope?		Open	Paric Corp.	Architect Punch List	19 Jul 2017	24 Jul 2017
001744	Wood grill split		Open	St Charles Acoustics	Architect Punch List	19 Jul 2017	24 Jul 2017
001743	Upper and lower wood grill sections on wall not in line		Open	St. Charles Acoustics L.L.C.	Architect Punch List	19 Jul 2017	24 Jul 2017
001749	Ceiling and wall items to be corrected per observation report 14		Open	St. Charles Acoustics L.L.C.	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > 160A_CORR. (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001816	Damaged door frames		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001817	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001818	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 160B_CONTROL (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001754	Install switch cover		Open	Guarantee Electric	Architect Punch List	19 Jul 2017	24 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001820	Coordinate wood panels with window frame		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 174_TEACHING KITCHEN (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001861	Missing electrical outlet at end of island		Open	Guarantee Electric	Architect Punch List	20 Jul 2017	25 Jul 2017
001862	Missing electrical outlets at open knee space (2 locations)		Open	Guarantee Electric	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 177_WOMEN (5 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001872	No door lock needed		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001873	Damaged door frames		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001874	Chips in door		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001875	Counter sealant missing		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001877	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 178_MECHANICAL ROOM (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001900	Seal all penetrations		In Dispute	ICON Mechanical	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 179_MEN (9 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001867	Scratch in toilet partition		Open	Deluca Plumbing	Architect Punch List	20 Jul 2017	25 Jul 2017
001866	Patch all grout holes		Open	Flooring Systems, Inc.	Architect Punch List	20 Jul 2017	25 Jul 2017
001864	Scratch on mirror		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001865	Chip in j-channel		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001870	Multiple chips in door		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001871	Rubber frame gasget missing		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001876	Counter sealant missing		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001868	Access panel not to be painted		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001869	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 180_TOILET (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001879	Chips in tile		Open	Flooring Systems, Inc.	Architect Punch List	20 Jul 2017	25 Jul 2017
001878	Mirror missing		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001880	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 182_TOILET (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001882	Mirror missing		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001885	Damaged door frame		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001883	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001884	Clean paint on door		Open	Titan Contractor Services	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 183B_CADAVER LAB WORKROOM (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001887	Move wiremold down to backsplash		Open	Guarantee Electric	Architect Punch List	20 Jul 2017	25 Jul 2017
001888	Walls are not complete		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001886	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 183C_BIO VESTIBULE (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001898	Polish countertop edges		Open	<not set>	Architect Punch List	20 Jul 2017	25 Jul 2017
001897	Chip in shelf		Open	Carroll Seating	Architect Punch List	20 Jul 2017	25 Jul 2017
001896	Walls not complete		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001899	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 185_SPILL CLOSET (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001881	Paint door		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 186_CUST. STOR. (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001901	Fire caulk all penetrations		In Dispute	ICON Mechanical	Architect Punch List	20 Jul 2017	25 Jul 2017
001902	Do not paint on any fire labels		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001903	Paint door		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > 191_CADAVER LAB (6 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001892	Seal around flex exhaust		Open	<not set>	Architect Punch List	20 Jul 2017	25 Jul 2017
001891	Adjust cabinet doors		Open	Carroll Seating	Architect Punch List	20 Jul 2017	25 Jul 2017
001894	Shelf missing		Open	Carroll Seating	Architect Punch List	20 Jul 2017	25 Jul 2017
001890	Missing paper towel dispenser		Open	Deluca Plumbing	Architect Punch List	20 Jul 2017	25 Jul 2017
001893	Walls are not complete		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001889	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > C130_CORRIDOR (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001739	Custom terrazzo base needed at column		Open	Missouri Terrazzo Co.	Architect Punch List	19 Jul 2017	24 Jul 2017

Webster > LEVEL_01 > C140_CORRIDOR (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001853	Eliminate gap at end of cove light		Open	Guarantee Electric	Architect Punch List	20 Jul 2017	25 Jul 2017
001852	Repair scuff marks, paint, and scratches in wood paneling		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001854	Repair chips in paneling trim		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > C150_LOBBY (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001846	Panel not properly cut		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > C151_COMMONS (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001842	Repair damaged wood panels		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001844	Panel is not flush		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001841	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017
001843	Clean paint from wood panels		Open	Titan Contractor Services	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > C170_CORRIDOR (7 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001858	Water damage at EAB connector door		Open	<not set>	Architect Punch List	20 Jul 2017	25 Jul 2017
001856	Eliminate gap at the end of cove light		Open	Guarantee Electric	Architect Punch List	20 Jul 2017	25 Jul 2017
001847	Metal panel not flush at elevator 1		Open	Otis Elevator Company	Architect Punch List	20 Jul 2017	25 Jul 2017
001848	Seal gap at elevator 1		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001855	Repair chips in wood paneling		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001857	Missing aluminum trim at wood panels		Open	PARIC (Self-Perform)	Architect Punch List	20 Jul 2017	25 Jul 2017
001859	Finish around sprinkler		Open	Titan Contractor Services	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > C180_CORRIDOR (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001905	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017
001904	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	20 Jul 2017	25 Jul 2017

Webster > LEVEL_01 > S176_STAIR 3-1 (6 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001907	Close the ends of the stair stringers		Open	<not set>	Architect Punch List	20 Jul 2017	25 Jul 2017
001909	Provide fire rated closure		Open	<not set>	Architect Punch List	20 Jul 2017	25 Jul 2017
001910	Provide fire rated sealant between CMU wall and floor		Open	<not set>	Architect Punch List	20 Jul 2017	25 Jul 2017
001911	Provide fire rated sealant between drywall and floor		Open	<not set>	Architect Punch List	20 Jul 2017	25 Jul 2017
001908	Install fasteners for handrail		Open	Atlas Iron Works	Architect Punch List	20 Jul 2017	25 Jul 2017
001906	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	20 Jul 2017	25 Jul 2017