Webster > LEVEL_02 (14 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001452	Seal end caps to mullion mates (entire level 2)		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001453	Seal drywall connection to mullion (entire level 2)		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001515	Readjust automatic door openers at all locations (if necessary)		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001584	Flooring is exposed at m seal locations		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001454	Scuff marks on storefront aluminum frames (entire level 2)		Open	National Glass & Glazing, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001455	Seal storefront frames to drywall (entire level 2)		Open	National Glass & Glazing, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001600	Sealant between flooring and store front framing to be gray not white (entire floor)		Open	National Glass & Glazing, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001465	Repaint 2" aluminum trim below gray painted facia (entire level 2)		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001475	Seal ends of 2" aluminum trim below facia (entire level 2)		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001591	Projectable surface covering not installed in all labs		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001606	End panels are missing at base cabinets on the teaching wall in all labs		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001451	Paint end caps at mullion mates (entire level 2)		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001464	Clean gray paint bleed along painted facia (entire level 2)		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001466	Raw cut edges of ceiling tiles not painted (entire level 2)		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 200A_WORK / COPY (14 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001458	<no description>		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001431	Repair damaged backsplash		Open	Flooring Systems, Inc.	Architect Punch List	17 Jul 2017	22 Jul 2017
001437	Install base		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001439	Adjust base so cabinet door can work properly		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001443	Patch grout		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001444	Base missing around cabinets		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001432	Seal countertop to wall at all locations		Open	PARIC (Self-Perform)	Architect Punch List	17 Jul 2017	22 Jul 2017
001435	Repair drywall at data cover		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001436	Repair drywall at receptical		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001456	Door corner chipped		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001433	Remove adhesive from wall under cork board		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001438	Clean paint off cabinets		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001442	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001434	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 200B_DATA (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001441	Scuff marks on interior door frame		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001440	Repair paint chips on door		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 202_RECEPTION (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001494	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001493	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 203_CONF (8 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001446	Seal gap around ceiling main		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001457	Attach shade brackets		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001488	<no description>		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001447	Repaint soffit		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001449	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001445	Visible crack at light		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017
001448	Bent wall angle		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017
001450	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 205_OFF. GLOBAL (5 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001463	Attach shade brackets		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001459	Column needs wood base		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001461	Repair door chips		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001460	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001462	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 206_OFF. DEAN'S ASSIST. (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001471	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 207_OFF. STRATEGIC (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001469	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001470	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 208_OFF. ASSESSMENT (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001472	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001473	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 209_OFF. ASSOC. DEAN (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001468	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001467	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 210A_STORAGE (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001474	Door frame dent		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 211_OFF. ASSOC. DEAN (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001478	Dented drywall sill		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001476	Paint drips on carpet and base		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001477	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 212_OFF. COMMUNICATIONS (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001482	Door chip		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001480	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001481	Paint on carpet		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001479	Paint raw cut edge ceiling tiles		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 214_OFF. OPERATIONS (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001487	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001486	Seal ceiling to drywall		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 215_DEAN'S OFFICE (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001483	Mullion mate missing		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001485	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001484	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 231_COMP. LAB / GEN. CLASSROOM (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001498	Incomplete items; walls, soffits, column, shades, paint, yellow metal panels		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001499	Ends of shade pockets are open - need to be closed		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001501	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 233_GEN. CLASSROOM (24 Seat) (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001500	Incomplete items; walls, soffits, column, shades, paint, yellow metal panels, project screens		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001509	Ends of shade pockets are open - need to be closed		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001502	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 235_GEN. CLASSROOM (24 Seat) (8 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001505	Incomplete items; walls, soffits, column, shades, paint, yellow metal panels, glass around column		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001510	Ends of shade pockets are open - need to be closed		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001511	DI water outlet valve missing		Open	Deluca Plumbing	Architect Punch List	18 Jul 2017	23 Jul 2017
001512	Flooring transition repair		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001503	Seal between curtain wall and storefront		Open	National Glass & Glazing, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001504	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017
001506	Paint all raw cut edges of ceiling tiles		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017
001507	Clean angled glass behind column		Open	Titan Contractor Services	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 272A_CHEM STOCK ROOM (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001574	Black closure strip behind door missing		Open	Carroll Seating	Architect Punch List	18 Jul 2017	23 Jul 2017
001568	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001570	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 272B_LAB STOR. (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001573	Missing lab tables		Open	Carroll Seating	Architect Punch List	18 Jul 2017	23 Jul 2017
001571	Missing screws at shelving		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001575	Missing floor door stop		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001572	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 274_MICROSCOPY ROOM (7 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001566	Needs to be a white valve instead of Crome		Open	ICON Mechanical	Architect Punch List	18 Jul 2017	23 Jul 2017
001561	Repair door chips		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001564	Missing closure plate for door bottom		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001567	Dented door frame		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001562	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001565	Clean paint off wiremold		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001563	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 275_LACT. (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001645	Incomplete items; base, paint, electrical covers,		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001646	Door frame damage		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 276_SCIN CLASSROOM (5 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001594	Repair scuff marks on unistrut system		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001580	Scratches on table mounted electrical outlet plates		Open	Guarantee Electric	Architect Punch List	18 Jul 2017	23 Jul 2017
001577	Chalk tray missing		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001578	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001579	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 277_WOMEN (5 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001640	Patch grout holes		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001642	Patch grout at tile base		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001641	Missing light		Open	Guarantee Electric	Architect Punch List	18 Jul 2017	23 Jul 2017
001643	Door frame damage		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001644	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 279_MEN (11 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001628	Patch holes in grout		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001631	Clean up excess grout		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001633	Remove tile spacer		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001634	Repair chipped tile		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001635	Repair drywall at sink		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001636	Seal countertop to wall		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001637	Door chip		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001638	Damaged door frame		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001630	All access panels with enamel finish were not supposed to be painted		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001629	Clean light lense		Open	Titan Contractor Services	Architect Punch List	18 Jul 2017	23 Jul 2017
001632	Clean floor and tile base		Open	Titan Contractor Services	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 282_PHYS LAB PREP (5 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001585	Missing shade		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001582	Missing tables under wiremold		Open	Carroll Seating	Architect Punch List	18 Jul 2017	23 Jul 2017
001581	Door frame banged up		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001583	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001588	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 283_MICROBIO/ PLANT RESEARCH LAB (3 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001610	Repair drywall under wiremold		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001609	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001608	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 284_PHYSICS LAB (5 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001592	Seal around structural brace		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001593	Repair scuff marks on unistrut system		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001586	Gap in wiremold		Open	Guarantee Electric	Architect Punch List	18 Jul 2017	23 Jul 2017
001589	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001590	Repaint window sill		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 289A_MICROBIO PREP (6 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001624	Missing flammable storage cabinets		Open	Carroll Seating	Architect Punch List	18 Jul 2017	23 Jul 2017
001622	Light switch does not work properly		Open	Guarantee Electric	Architect Punch List	18 Jul 2017	23 Jul 2017
001625	Missing cover plate		Open	Guarantee Electric	Architect Punch List	18 Jul 2017	23 Jul 2017
001623	Chip in door		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001626	Repair door frame		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001627	Seal door frame to drywall		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 289B_TISSUE CULTURE B (7 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001619	Flammable storage cabinet missing (and at all locations)		Open	Carroll Seating	Architect Punch List	18 Jul 2017	23 Jul 2017
001615	Eyewash missing		Open	Deluca Plumbing	Architect Punch List	18 Jul 2017	23 Jul 2017
001617	Dented door frame		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001621	Seal column to wall		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001618	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001616	Reinstall ceiling grid		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017
001620	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 291_CELL BIO / PHYS RESEARCH LAB (8 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001611	Relocate paper towel dispenser to other side of rack		Open	Deluca Plumbing	Architect Punch List	18 Jul 2017	23 Jul 2017
001612	Pipe stub purpose?		Open	Deluca Plumbing	Architect Punch List	18 Jul 2017	23 Jul 2017
001614	Flooring is missing on backside of drain		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001613	Finish electrical boxes		Open	Guarantee Electric	Architect Punch List	18 Jul 2017	23 Jul 2017
001605	Repair drywall above cabinets on teaching wall		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001607	Drywall repair at wiremold		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001604	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001603	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > 292_PHYS RESEARCH LAB (7 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001595	Seal around structural brace (top and bottom)		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001596	Missing tables under wall mounted shelves		Open	Carroll Seating	Architect Punch List	18 Jul 2017	23 Jul 2017
001598	Seismic lips are missing on wall mounted shelves		Open	Carroll Seating	Architect Punch List	18 Jul 2017	23 Jul 2017
001602	Reweld flooring behind brace		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001599	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001601	Clean paint off flooring		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001597	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > C210_CORR (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001496	Door chips @ c210		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001497	Door frame damage @C210		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001491	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001492	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > C230_CORR (4 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001514	Soffit incomplete		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001517	Scuff mark on mullion		Open	National Glass & Glazing, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001516	South wall missing sound acoustic pads (ID0102)		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001513	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > C250_LOBBY (2 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001557	Not complete		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001558	Repair scratches, scuff marks, and chips in wood paneling		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > C270_CORR (5 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001560	Fill gap between elevator and terrazzo		Open	Flooring Systems, Inc.	Architect Punch List	18 Jul 2017	23 Jul 2017
001555	Panel above elevator is not flush with the frame		Open	Otis Elevator Company	Architect Punch List	18 Jul 2017	23 Jul 2017
001556	Repair scratches, scuff marks, and chips on wood panels		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001559	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001576	Repair paint scuff marks, drips, and damages in common area		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > C280_CORR (11 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001656	Gap at floor and elevator door frames		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001657	Cover plates are too wide		Open	<not set>	Architect Punch List	18 Jul 2017	23 Jul 2017
001648	Seal around wood panelling at lab entries		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001649	Missing wood panelling around bathroom entries		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001655	Repair chips in wood panels		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001658	Seal between wood panelling and wall		Open	PARIC (Self-Perform)	Architect Punch List	18 Jul 2017	23 Jul 2017
001650	Repair paint scuff marks, drips, and damages		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001651	Level 5 finish on all walls		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001652	Clean and repair drywall around columns		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001653	Clean all paint on wood panels		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017
001647	Repair damaged ceiling components		Open	St Charles Acoustics	Architect Punch List	18 Jul 2017	23 Jul 2017

Webster > LEVEL_02 > C280A_COMMONS (1 issues)

Issue ID	Description	Location Detail	Status	Company	Type	Date Created	Due Date
001654	Paint facia and soffit at north vertical window to be gray		Open	Spectra Painting	Architect Punch List	18 Jul 2017	23 Jul 2017