HOHMANN & BARNARD, INC.
A MiTek - BERKSHIRE HATHAWAY COMPANY

Control and Expansion Joints

NS - Closed Cell Neoprene Sponge



NSTA (WITH TEAR STRIP)



NS (STD. WITHOUT TEAR STRIP)



DRAWINGS FOR ILLUSTRATIVE PURPOSES ONLY

Material:

Closed Cell (ASTM D1056 Grade 2A 1)

- ☐ NS - Without tear strip (standard)
- ☐ NSTA - With tear strip
- ☐ Optional: Pressure-Sensitive Adhesive on one side

Thickness:

- ☐ 1/4"
- ☐ 3/8"
- ☐ 1/2"
- ☐ Other _____

Width:

- ☐ 3"
- ☐ 4"
- ☐ 6"
- ☐ Other _____

HOHMANN & BARNARD, Inc.
30 Rasons Court | Hauppauge, NY 11788
CORPORATE HEADQUARTERS
T: 800.645.0616 F: 631.234.0683
www.h-b.com

Branch/Subsidiary Locations:
ALABAMA - ILLINOIS - MARYLAND
NEW YORK - PENNSYLVANIA - TEXAS
CANADA

© HOHMANN & BARNARD, INC. - 2012

CANNONDESIGN

SUBMITTAL IDENTIFICATION SHEET

To be completed by Contractor/CM

WEBSTER UNIVERSITY ISB
PROJECT NAME

8274 BIG BEND BLVD
ADDRESS

NUMBER

WEBSTER UNIVERSITY
OWNER

CANNON DESIGN
ARCHITECT / ENGINEER

Joe Voypick
SUBMITTED BY

042000-015
CONTRACTOR / CM SUBMITTAL NO.

CANNON DESIGN SUBMITTAL NO.

DRAWING / DETAIL REFERENCE

042000
SPECIFICATION SECTION / PARAGRAPH

Leonard Masonry
MANUFACTURER / SUPPLIER

ITEM / PRODUCT ID

REQUIRED DATE

PRIORITY

◯ CRITICAL

ITEM BEING SUBMITTED (check only one)

- ◯ Shop Drawings
- ◯ Samples (_____ copies)
- ◯ LEED Submittal
- ◯ Certification / Qualifications
- ◯ Record Documents
- ◉ Product Data
- ◯ Coordination Drawing
- ◯ Calculations
- ◯ Schedules
- ◯ O&M Manuals
- ◯ Other _____

ITEM BEING SUBMITTED FOR (check only one)

◉ Action ◯ Information Only ◯ Record

REMARKS OR DEVIATIONS

CONTRACTOR / CM CERTIFICATION
(SUBMITTALS NOT CERTIFIED WILL BE RETURNED WITHOUT REVIEW)

PARIC

PARIC CORPORATION
SUBMITTAL STAMP

THIS SHOP DRAWING HAS BEEN REVIEWED BY PARIC CORPORATION

Subcontractor remains responsible for dimensions, quantities, coordination with other trades and compliance with contract documents.

By:
Devin D. Gates

Joe Voypick
REVIEWED BY

7/8/16
DATE

To be completed by Reviewer

04 2000-015
CANNON DESIGN SUBMITTAL NUMBER

7/8/16
RECEIVED DATE

- ◯ A. No Exceptions Taken
  No further review of submittal is required.
- ◉ B. Make Corrections Noted
  Incorporate corrections in work; resubmission is not required.
- ◯ C. Revise and Resubmit
  Revise as noted, and resubmit for review.
- ◯ D. Rejected
  Submittal is not in compliance with Contract Documents; provide new submittal.
- ◯ E. For Record / Information Only
  Submittal was reviewed for Record / Information purposes only.
- ◯ F. Not Required for Review
  Submittal is not required by Contract Documents and has not been reviewed.

Review is for conformance with the design concept of this project and for general compliance with contract documents. Contractor is responsible for quantities, dimensions and compliance with contract documents and for information that pertains to fabrication processes, construction techniques and coordination of this work with all trades which will be affected thereby. This review is null and void if submittal deviates from contract documents and does not indicate or note deviations.

A/E COMMENTS ◯ See attached sheet(s) for additional comments

See comments in "green" below

REVIEWED BY

07/28/16
DATE

77 Westport Plaza
Suite 250
St. Louis, MO 63146

TRANSMITTAL

No. 15051-0127

Paric Corporation

PROJECT: 15051-Webster University Interdisciplinary Science Building

DATE: 07/08/2016

TO: Cannon Design
1100 Clark Ave
St Louis MO 63102

RE: Clay Face Brick Product Data

ATTN: Kelvin Patel

JOB: 15051

WE ARE SENDING:	SUBMITTED FOR:	ACTION TAKEN:
☐ Shop Drawings	☑ Approval	☐ Approved as Submitted
☐ Letter	☐ Your Use	☐ Approved as Noted
☐ Prints	☐ As Requested	☐ Returned After Loan
☐ Change Order	☐ Review and Comment	☐ Resubmit
☐ Plans		☐ Submit
☐ Samples	**SENT VIA:**	☐ Returned
☐ Specifications	☐ Attached	☐ Returned for Corrections
☑ Other: Product Data	☐ Separate Cover Via:	☐ Due Date:

Item	*Package*	*Code*	*Rev.*	*Copies*	*Date*	*Description*	*Status*
Submittal		042000-015	1		07/08/2016	Clay Face Brick Product Data	Submitted

NOTES:

CC:

Signed: _____
Devin Gates

TRANSMITTAL LETTER

Leonard Masonry, Inc.

5925 Fee Fee Road
St. Louis, MO 63042

Transmittal # **945-02**

Date: 7/7/2016
Phone: (314) 731-5500
Fax: (314) 731-3366

Project Name: Webster University Interdisciplinary Science Building **Project #:** 945

To: Paric Corporation
Attn: Devin Gates
77 Westport Plaza Drive
Suite 250
St. Louis, MO 63146

SUBJECT: Submittal 945-02, Rev #0 Masonry materials

Phone: (636) 561-9500 **Fax:** (636) 561-9501

Items listed are being sent
- ☑ Enclosed
- ☐ Under Separate Cover
- ☐ Via

We are transmitting the following to you:

- ☑ Product Data
- ☐ Samples
- ☑ Submittals: Submittal 945-02, Rev #0 Masonry materials
- ☐ Shop Drawings
- ☐ O & M Manuals
- ☐ Plans
- ☐ Architectural Drawings
- ☐ Letters
- ☐ Specifications
- ☐ Prints
- ☐ Addenda
- ☐ Engineering Drawings
- ☐ Change Order Requests
- ☐

Submittal: Masonry materials - Rev#0

Code/Spec	Copies	For	Product #	Summary Item
042000-2.3	1	Approval		Face brick test report
042000-2.4	1	Approval		Type N mortar certification
042000-2.4	1	Approval		Type S mortar certification
042000-2.4E	1	Approval		Mortar color product data
042000-2.6C	1	Approval		Veneer anchor product data
042000-2.7	1	Approval		Flashing product data
042000-2.8A	1	Approval		Compressible filler product data
042000-2.8B	1	Approval		Bond-breaker product data
042000-2.8C	1	Approval		Weep vent product data
042000-2.8D	1	Approval		Cavity drainage material product data
042000-2.8	1	Approval		Termination bar product data
042000-2.9A	1	Approval		Cavity wall insulation product data
042000-2.9B	1	Approval		Insulation adhesive product data
042000-3.12E.5	1	Approval		Masonry cleaner product data

Remarks:

Specified veneer tie is not available with 1/4" diameter ties per manufacturers data sheet.

Potable water is to be supplied by owner/GC. No submittal provided.

TRANSMITTAL LETTER

Leonard Masonry, Inc.

5925 Fee Fee Road
St. Louis, MO 63042

Transmittal # **945-02**

Date: 7/7/2016
Phone: (314) 731-5500
Fax: (314) 731-3366

Project Name: Webster University Interdisciplinary Science Building **Project #:** 945

To: Paric Corporation
Attn: Devin Gates
77 Westport Plaza Drive
Suite 250
St. Louis, MO 63146

SUBJECT: Submittal 945-02, Rev #0 Masonry materials

Phone: (636) 561-9500 **Fax:** (636) 561-9501

Items listed are being sent
- ☑ Enclosed
- ☐ Under Separate Cover
- ☐ Via

We are transmitting the following to you:

- ☑ Product Data
- ☐ Samples
- ☑ Submittals: Submittal 945-02, Rev #0 Masonry materials
- ☐ Shop Drawings
- ☐ O & M Manuals
- ☐ Plans
- ☐ Architectural Drawings
- ☐ Letters
- ☐ Specifications
- ☐ Prints
- ☐ Addenda
- ☐ Engineering Drawings
- ☐ Change Order Requests
- ☐

COPIES TO:

By: Ken Westhoff
Project Manager

Received by: _____ Date: _____