


HOME COMPANY INFO PRODUCTS SPECS/CADS HOW TO ORDER CONTACT US LINKS CONTINUING EDUCATION

WEEP VENT PRODUCT OVERVIEW



Mortar Net® Weep Vents™ are the easy way to ensure masonry cavity walls drain correctly and maintain their finished appearance.

Unprotected weep holes are easily blocked by insects or debris, resulting in damage from water buildup and improper air movement. Mortar Net® Weep Vents™ help ensure that weep holes stay open and that walls always breathe, drain, and dry quickly and thoroughly.

Mortar Net® Weep Vents™ are available in a choice of attractive colors to match the mortar or brick beings used, eliminating open holes and dark shadows.



Please provide
color selection.



Architect Please Verify

AVOID MASONRY
WALL DRAINAGE
PROBLEMS WITH

Mortar Net®
WEEP
VENTS™



Mort

Net®
D



SUBMITTAL IDENTIFICATION SHEET

To be completed by Contractor/CM

WEBSTER UNIVERSITY ISB	
PROJECT NAME	
8274 BIG BEND BLVD	
ADDRESS	
NUMBER	
WEBSTER UNIVERSITY	
OWNER	
CANNON DESIGN	
ARCHITECT / ENGINEER	
Joe Voypick	
SUBMITTED BY	
042000-013	
CONTRACTOR / CM SUBMITTAL NO.	CANNON DESIGN SUBMITTAL NO.
	042000
DRAWING / DETAIL REFERENCE	SPECIFICATION SECTION / PARAGRAPH
Leonard Masonry	
MANUFACTURER / SUPPLIER	ITEM / PRODUCT ID
REQUIRED DATE	PRIORITY
	CRITICAL

ITEM BEING SUBMITTED (check only one)

- | | | |
|--|--|--|
| ☒ Shop Drawings | ☐ Certification / | ☐ Coordination Drawing |
| ☐ Samples | ☐ Qualifications | ☐ Calculations |
| (_____ copies) | ☐ Record Documents | ☐ Schedules |
| ☐ LEED Submittal | ☐ Product Data | ☐ O&M Manuals |
| ☐ Other _____ | | |

ITEM BEING SUBMITTED FOR (check only one)

- ☒ Action ☐ Information Only ☐ Record

REMARKS OR DEVIATIONS

CONTRACTOR / CM CERTIFICATION (SUBMITTALS NOT CERTIFIED WILL BE RETURNED WITHOUT REVIEW)



PARIC CORPORATION
SUBMITTAL STAMP

THIS SHOP DRAWING HAS BEEN REVIEWED BY PARIC CORPORATION

Subcontractor remains responsible for dimensions, quantities, coordination with other trades and compliance with contract documents.

By:

Devin D. Gates

To be completed by Reviewer

04 2000-013
CANNON DESIGN SUBMITTAL NUMBER
6/17/16
RECEIVED DATE

- ☐ A. No Exceptions Taken
No further review of submittal is required.
- ☐ B. Make Corrections Noted
Incorporate corrections in work; resubmission is not required.
- ☒ C. Revise and Resubmit
Revise as noted, and resubmit for review.
- ☐ D. Rejected
Submittal is not in compliance with Contract Documents; provide new submittal.
- ☐ E. For Record / Information Only
Submittal was reviewed for Record / Information purposes only.
- ☐ F. Not Required for Review
Submittal is not required by Contract Documents and has not been reviewed.

Review is for conformance with the design concept of this project and for general compliance with contract documents. Contractor is responsible for quantities, dimensions and compliance with contract documents and for information that pertains to fabrication processes, construction techniques and coordination of this work with all trades which will be affected thereby. This review is null and void if submittal deviates from contract documents and does not indicate or note deviations.

A/E COMMENTS

☐ See attached sheet(s) for additional comments

Per previous submittal 007

1. Please flag correct item submitted and reference correct specification number 04 20 00.
2. Please carefully review specification section 04 20 00 and submit manufacturer's product documentation, samples, certifications and accessories as one package.

Per submittal 013

1. Please comply with items 1 and 2 above
2. submit product data for each item listed in specification section 04200. example of items not included 2.4 D,F & G
- 3 Provide documentation proving compliance with specifications

Joe Voypick	6/17/16
REVIEWED BY	DATE

Kathy Williams	06/28/16
REVIEWED BY	DATE



77 Westport Plaza
Suite 250
St. Louis, MO 63146

TRANSMITTAL

No. 15051-0088

Paric Corporation

PROJECT: 15051-Webster University Interdisciplinary Science Building

DATE: 06/17/2016

TO: Cannon Design
1100 Clark Ave
St Louis MO 63102

RE: Masonry product data REVI

ATTN: Kelvin Patel

JOB: 15051

WE ARE SENDING:	SUBMITTED FOR:	ACTION TAKEN:
☒ Shop Drawings	☒ Approval	☒ Approved as Submitted
☐ Letter	☐ Your Use	☐ Approved as Noted
☐ Prints	☐ As Requested	☐ Returned After Loan
☐ Change Order	☐ Review and Comment	☐ Resubmit
☐ Plans		☐ Submit
☐ Samples	SENT VIA:	☐ Returned
☐ Specifications	☐ Attached	☐ Returned for Corrections
☐ Other:	☐ Separate Cover Via:	☐ Due Date:

<i>Item</i>	<i>Package</i>	<i>Code</i>	<i>Rev.</i>	<i>Copies</i>	<i>Date</i>	<i>Description</i>	<i>Status</i>
Submittal		042000-13	2		06/17/2016	Masonry product data REVI	Submitted


NOTES:

CC: Paric Corporation, Kathy Bathe

Project Coordinator: Paric Corporation, Kathy Bathe

Signed: _____
Devin Gates

TRANSMITTAL LETTER



Leonard Masonry, Inc.

5925 Fee Fee Road
St. Louis, MO 63042

Transmittal # **945-01**

Date: 6/10/2016
Phone: (314) 731-5500
Fax: (314) 731-3366

Project Name: Webster University Interdisciplinary Science Building

Project #: 945

To: Paric Corporation
Attn: Devin Gates
77 Westport Plaza Drive
Suite 250
St. Louis, MO 63146

Items listed are being sent

- ☒ Enclosed
☐ Under Separate Cover
☐ Via

SUBJECT: Submittal 945-01, Rev #0 Masonry materials

Phone: (636) 561-9500 **Fax:** (636) 561-9501

We are transmitting the following to you:

- ☒ Product Data
☐ Architectural Drawings
☐ Engineering Drawings
☐ Samples
☐ Letters
☐ Change Order Requests

- ☒ Submittals: Submittal 945-01, Rev #0 Masonry materials
☐ Shop Drawings
☐ Specifications
☐ O & M Manuals
☐ Prints
☐ Plans
☐ Addenda
☐

Submittal: Masonry materials - Rev#0

Code/Spec	Copies	For	Product #	Summary Item
	1	Approval		Face brick test report
	1	Approval		Type N mortar certification
	1	Approval		Mortar color product data
	1	Approval		Veneer anchor product data
	1	Approval		Weep vent product data
	1	Approval		Cavity drainage material product data
	1	Approval		Termination bar product data
	1	Approval		Cavity-wall insulation product data
	1	Approval		Masonry cleaner product data

Remarks:

COPIES TO:

By: Ken Westhoff
Project Manager

Received by: _____

Date: _____



77 Westport Plaza
Suite 250
St. Louis, MO 63146

TRANSMITTAL

No. 15051-0129

Paric Corporation

PROJECT: 15051-Webster University Interdisciplinary Science Building

DATE: 07/08/2016

TO: Cannon Design
1100 Clark Ave
St Louis MO 63102

RE: Weep Vent Product Sample

ATTN: Kelvin Patel

JOB: 15051

WE ARE SENDING:	SUBMITTED FOR:	ACTION TAKEN:
☐ Shop Drawings	☒ Approval	☐ Approved as Submitted
☐ Letter	☐ Your Use	☐ Approved as Noted
☐ Prints	☐ As Requested	☐ Returned After Loan
☐ Change Order	☐ Review and Comment	☐ Resubmit
☐ Plans		☐ Submit
☒ Samples	SENT VIA:	☐ Returned
☐ Specifications	☐ Attached	☐ Returned for Corrections
☐ Other:	☐ Separate Cover Via:	☐ Due Date:

Item	Package	Code	Rev.	Copies	Date	Description	Status
Submittal		042000-017	1		07/08/2016	Weep Vent Product Sample	Submitted

NOTES:

CC:

Signed: _____
Devin Gates