

WEBSTER SCIENCE
ST. LOUIS
WOODWORKS
500 Prospect Avenue - St. Louis, MO 63110
PLAM CABS
064116

SECTION
064116

SUBMITTAL IDENTIFICATION SHEET

To be completed by Contractor/CM

WEBSTER UNIVERSITY ISB	
PROJECT NAME	
8274 BIG BEND BLVD	
ADDRESS	
NUMBER	
WEBSTER UNIVERSITY	
OWNER	
CANNON DESIGN	
ARCHITECT / ENGINEER	
DEVIN D GATES	
SUBMITTED BY	
064116-001	
CONTRACTOR / CM SUBMITTAL NO.	CANNON DESIGN SUBMITTAL NO.
	064116
DRAWING / DETAIL REFERENCE	SPECIFICATION SECTION / PARAGRAPH
MANUFACTURER / SUPPLIER	ITEM / PRODUCT ID
REQUIRED DATE	PRIORITY
	CRITICAL

ITEM BEING SUBMITTED (check only one)

- | | | |
|--------------------------------------|--|--|
| ☐ Shop Drawings | ☒ Certification / | ☐ Coordination Drawing |
| ☐ Samples | ☐ Qualifications | ☐ Calculations |
| ☐ (____ copies) | ☐ Record Documents | ☐ Schedules |
| ☐ LEED Submittal | ☐ Product Data | ☐ O&M Manuals |
| ☐ Other _____ | | |

ITEM BEING SUBMITTED FOR (check only one)

- ☒ Action ☐ Information Only ☐ Record

REMARKS OR DEVIATIONS

plastic laminate, white melamine, MDF paint grade, cabinet front, cabinet handle, hing/plate, touch latch, drawer slides, shelf pin, lock, grommet, invisible hinge, closet rod & flange with bracket.

CONTRACTOR / CM CERTIFICATION (SUBMITTALS NOT CERTIFIED WILL BE RETURNED WITHOUT REVIEW)



PARIC CORPORATION
SUBMITTAL STAMP

THIS SHOP DRAWING HAS BEEN REVIEWED BY PARIC CORPORATION

Subcontractor remains responsible for dimensions, quantities, coordination with other trades and compliance with contract documents.

By:

Devin D. Gates

To be completed by Reviewer

06 4116-001
CANNON DESIGN SUBMITTAL NUMBER
12/1/16
RECEIVED DATE

- ☐ A. No Exceptions Taken
No further review of submittal is required.
- ☐ B. Make Corrections Noted
Incorporate corrections in work; resubmission is not required.
- ☒ C. Revise and Resubmit
Revise as noted, and resubmit for review.
- ☐ D. Rejected
Submittal is not in compliance with Contract Documents; provide new submittal.
- ☐ E. For Record / Information Only
Submittal was reviewed for Record / Information purposes only.
- ☐ F. Not Required for Review
Submittal is not required by Contract Documents and has not been reviewed.

items noted on following page - see below for information required.

Review is for conformance with the design concept of this project and for general compliance with contract documents. Contractor is responsible for quantities, dimensions and compliance with contract documents and for information that pertains to fabrication processes, construction techniques and coordination of this work with all trades which will be affected thereby. This review is null and void if submittal deviates from contract documents and does not indicate or note deviations.

A/E COMMENTS

☐ See attached sheet(s) for additional comments

See following page.
Revised samples are not required unless indicated specifically.
Provide product data for all products per specification
Provide sustainable design submittals per specification.

DEVIN D GATES

REVIEWED BY

11/14/16

DATE

Lynn Grossman

REVIEWED BY

Digitally signed by Lynn Grossman
DN: C=US, E=lgrossman@cannondesign.com, O=Cannon
Design, CN=Lynn Grossman
Date: 2016.12.02 10:04:11 -06'00'

12.02.16

DATE

White Laminate for casework shown on elevations 5 and 6 on sheet A0607: Wilsonart
Linen D427-60

Comments on items:

- cabinet front 1.3 - D.4 : No exception: Edge banding to match exposed laminate
- mdf - paint grade: no exceptions. Provide product information/location
- counter support bracket: does not match specified product. not correct configuration, detail indicates flush mount. Provide product data - **Revise and Resubmit product information demonstrating compliance with specification.**
- Closet shelf and rod bracket: does not match specified product- wrong finish, wrong configuration, no product information provided. **Revise and Resubmit product information demonstrating compliance with specification.**
-
- Closet rod: no exceptions, no product information provided. Provide supporting product data.
- drawer slides: no product information to provided to demonstrate compliance with specifications
- **Provide supporting product data, see notes on shop drawings.**
- hinges: provide self closing hinges. demonstrate compliance with specs. submitted hinges appear be 170 degrees, but not self closing. Shop drawings indicated 125 deg opg. **Revise and resubmit product information demonstrating compliance with specification.**
- shelf rests: no exceptions
- cabinet lock: provide product information, verify that keying can be provided for owner requirements
- pull: no exceptions, provide product data
- invisible hinge: size of hinge is too small for application/use at panel detailed on 4/A0810.
Revise and Resubmit product information demonstrating appropriate size for use.
- touch latch (06 4113): provide demonstration that product meets specification and is comparable to other hardware quality. Provide product data.
- grommet: revise to 2 1/2" diameter, provide gray to match laminate.
- adjustable shelf standard and bracket. 1. verify that these are no longer required per shop drawings. Not reviewed. **If required, provide product data.**
- cabinet panel - no exceptions - provide product data on substrate and laminate.