

EMSEAL
emseal.com
Toll Free: 800-526-8365
EMSEAL Joint Systems, Ltd., 25 Bridge Lane, Needham Heights, MA 01901 USA Tel: (617) 838-0200

QuietJoint™ SHG
Sound, draft, heat, cold, and dust blocking acoustic joint filler for interior, non-moving joints and gaps. Colorized, versatile and ideally suited to filling gaps between the ends of permanent, semi-permanent, or movable partitions, walls of glass, & other conditions.

SOUND ATTENUATION **STC 53** **OITC 36**
1/2" x 3/4" x 1/2" and 1/2" x 3/4" x 1/4"



Dow Corning® 790 Silicone Building Sealant

STANDARD COLORS

Precast White / Branco Pálido / Blanco ostión
Blanc beton prefabrique

Limestone / Gelo / Cantera / Calcaire

White / Branco / Blanco / Blanc

Natural Stone / Pedra Natural / Cemento / Pierre naturelle

Gray / Cinza / Gris / Gris

Black / Preto / Negro / Noir

Bronze / Bronze / Café obscuro / Bronze

Sandstone / Arcia / Arena / Grès

Adobe Tan / Rosa Escuro / Rosa obscuro / Brun adobe

Dusty Rose / Rosa Claro / Rosa claro / Rose sable

Rustic Brick / Tijolo / Ladrillo / Rouille

Blue Spruce / Azul Petróleo / Verde esmeralda / Bleu sapin

Charcoal / Grafite / Grafito / Charbon

"Dow Corning" is a registered trademark of
Dow Corning Corporation, Midland, MI
© December 2008 Dow Corning Corporation.
All rights reserved.

Form No. 61-79411-01

790



PECORA
CORPORATION

Architectural Weatherproofing Products
U.S.A. • 1-800-456-7222

SILICONE SEALANTS

Standard Color Guide

890NST
NON-STAINING
TECHNOLOGY.

Tru White

345

Precast

113

Beige

595

Limestone

039

Anodized Aluminum

804

Aluminum Stone

515

Natural Stone

565

Sandstone

951

Charcoal Gray

950

Classic Bronze

046

Black

012

Hartford Green

196

Red Rock

955

SUBMITTAL IDENTIFICATION SHEET

To be completed by Contractor/CM

WEBSTER UNIVERSITY ISB	
PROJECT NAME	
8274 BIG BEND BLVD	
ADDRESS	
NUMBER	
WEBSTER UNIVERSITY	
OWNER	
CANNON DESIGN	
ARCHITECT / ENGINEER	
DEVIN D GATES	
SUBMITTED BY	
079500-007	
CONTRACTOR / CM SUBMITTAL NO.	CANNON DESIGN SUBMITTAL NO.
	079500
DRAWING / DETAIL REFERENCE	SPECIFICATION SECTION / PARAGRAPH
MANUFACTURER / SUPPLIER	ITEM / PRODUCT ID
REQUIRED DATE	PRIORITY
	☐ CRITICAL

ITEM BEING SUBMITTED (check only one)

- | | | |
|--|--|--|
| ☐ Shop Drawings | ☐ Certification / Qualifications | ☐ Coordination Drawing |
| ☒ Samples (____ copies) | ☐ Record Documents | ☐ Calculations |
| ☐ LEED Submittal | ☐ Product Data | ☐ Schedules |
| ☐ Other _____ | ☐ O&M Manuals | |

ITEM BEING SUBMITTED FOR (check only one)

- ☒ Action ☐ Information Only ☐ Record

REMARKS OR DEVIATIONS

Please select a color from chart. Note that the samples are to represent the material only, not the specified thickness.

CONTRACTOR / CM CERTIFICATION (SUBMITTALS NOT CERTIFIED WILL BE RETURNED WITHOUT REVIEW)



PARIC CORPORATION
SUBMITTAL STAMP

THIS SHOP DRAWING HAS BEEN REVIEWED BY PARIC CORPORATION

Subcontractor remains responsible for dimensions, quantities, coordination with other trades and compliance with contract documents.

By:

Devin D. Gates

To be completed by Reviewer

07 9500-007
CANNON DESIGN SUBMITTAL NUMBER
2/3/17
RECEIVED DATE

- ☐ A. No Exceptions Taken
No further review of submittal is required.
- ☒ B. Make Corrections Noted
Incorporate corrections in work; resubmission is not required.
- ☐ C. Revise and Resubmit
Revise as noted, and resubmit for review.
- ☐ D. Rejected
Submittal is not in compliance with Contract Documents; provide new submittal.
- ☐ E. For Record / Information Only
Submittal was reviewed for Record / Information purposes only.
- ☐ F. Not Required for Review
Submittal is not required by Contract Documents and has not been reviewed.

Review is for conformance with the design concept of this project and for general compliance with contract documents. Contractor is responsible for quantities, dimensions and compliance with contract documents and for information that pertains to fabrication processes, construction techniques and coordination of this work with all trades which will be affected thereby. This review is null and void if submittal deviates from contract documents and does not indicate or note deviations.

A/E COMMENTS

☐ See attached sheet(s) for additional comments

At exterior mullion location - use 'Charcoal Gray' color.

At Interior mullion location - use 'Tru White' color.

Use QuietJoint SHH or SHG as needed considering mullion thickness to achieve a gap-less finish at the joint.

DEVIN D GATES

REVIEWED BY

02/03/17

DATE

Kelvin Patel

REVIEWED BY

Digitally signed by Kelvin Patel
DN: cn=Kelvin Patel, o=Cannon Design,
ou=Architect, cn=Kelvin Patel
Date: 2017.02.23 13:01:47 -0600

2/23/2017

DATE