

- Marley Cooling Technologies
- Armstrong Pumps & Heat Exchangers
- Laars Heating Systems
- ClimateMaster Heat Pumps
- Square D Variable Speed Drives



- SMARDT Chillers
- Trend/ Novar Controls
- PEP Filters
- Boiler Room Accessories
- Cooling Tower Service

SUBMITTAL DATA

TO: **iCON Mechanical**
 ATTENTION: **Alex Chambers**
 PHONE:
 FAX:

SUBMITTAL DATE **May 20, 2016**
 CUSTOMER P.O. #
 REVISION
 PREPARED BY **Eric Eyler / BC**
 QUOTE NUMBER **16-0213.1**
 CURRENT LEAD TIME **Weeks**

PROJECT **Webster Univ ISB**
 ENGINEER **William Tao**
 LOCATION **Webster Groves, MO**

QTY.	TAG	DESCRIPTION
------	-----	-------------

Alfa Laval Heat Exchangers

1 PHX-1 **Alfa Laval Brazed Plate Model: CB30-34H T06**
 Cold Side: 44 F EWT 60 F LWT 13 gpm Water 2.39 psi PD
 Hot Side: 70 F EWT 60 F LWT 21 gpm Water 6.18 psi PD
 Weight: 12.7 lbs

This data is submitted for:

☒ **APPROVAL**

A purchase order commitment has been issued to MIDWEST MACHINERY COMPANY. Items will not be fabricated or delivered until this approval is returned verifying acceptance.

☐ **RECORD PURPOSES**

A purchase order commitment has been issued to MIDWEST MACHINERY COMPANY. Items are being fabricated or delivered. This data provided for record purposes.

☐ **RE-SUBMITTAL**

The items submitted are to record revisions, corrections, or requests for further information on items previously submitted.



Alfa Laval Plate Heat Exchanger Specification

Customer :
Project : (Untitled 0)
Item :

Date : 3/18/2016

Model: CB30-34H T06


		<u>Hot Side</u>	<u>Cold Side</u>
Fluid		Water	Water
Volume flow rate	GPM	21.0	13.0
Inlet temperature	°F	70.0	44.0
Outlet temperature	°F	60.0	60.1
Pressure drop	psi	6.18	2.39
Heat exchanged	kBtu/h		105.01

Density	lb/ft ³	62.3	62.4
Specific heat	Btu/lb, °F	1.00	1.00
Thermal conductivity	Btu/ft, h, °F	0.347	0.341
Viscosity	cP	0.981	1.13

Material plate / brazing	Alloy 316 / Cu
Connection material	Stainless Steel
ConnectionS1 (Cold-in)	Threaded (External)/ 1" NPT (F21) Alloy 316 NPT
ConnectionS2 (Cold-out)	Threaded (External)/ 1" NPT (F21) Alloy 316 NPT
ConnectionS3 (Hot-in)	Threaded (External)/ 1" NPT (F21) Alloy 316
ConnectionS4 (Hot-out)	Threaded (External)/ 1" NPT (F21) Alloy 316 NPT

Pressure vessel code		UL/CRN	
Design Pressure @ -320.000000	Psig	450.	450.
Design Pressure @ 400.000000	Psig	450.	450.
Design Temperature	°F	-320.0/400.0	
Overall length x width x height	in	5 x 4 x 12	
Net weight, empty / operating	lb	12.7 / 16.6	

Note that all unique customer requirements (i.e tolerance) need to be verified thru Alfa Laval.



HEATING SURFACE 23.72 ft²
NET WEIGHT 12.72 lb
OPERATING WEIGHT 16.64 lb

PLATE MATERIAL Alloy 316
PLATE GROUPING 1*16H / 1*17H

TOTAL LENGTH 4.63
TOTAL WIDTH 4.45
TOTAL HEIGHT 12.32

SUPPLIER	REF.	MP NO.
AGENT / REF.		
CUSTOMER NAME / REF. NO.		
SIGN.		

PLATE HEAT EXCHANGER




CB30-34H T06

UL/CRN

ITEM ID.
32870 9921 9

DATE
2016-03-18

REV
NO. 0



T1 T2 T3 T4 locations on back side
correspond to S1 S2 S3 S4 on front side

ALL DIMENSIONS IN INCHES

MEDIA	INLET	TEMP.	OUTLET	TEMP.	FLOW RATE	PRESSURE DROP	LIQUID VOL.
Water	S3	70.0 °F	S4	60.0 °F	21.0 GPM	6.178 psi	0.03051 ft³
Water	S1	44.0 °F	S2	60.1 °F	13.0 GPM	2.390 psi	0.03242 ft³

Shop Drawing Submittal Review

Transmitted To: Cannon Design

Date: February 8, 2017

Attention: stl-cac@cannondesign.com

Contact Person / WTA Field Inspector:
Patrick Garner

Project Name: Webster University-**ISB**

Reviewed by: Mike Nolte

Project No. WT 14127.01

☐

UPS

☐

Courier

☒

Email

Copies	No.	Description
1 PDF	235000M13	(Submittal No.'s:) (R&B C-SRC)
		(Cannon #235000-014) - (Paric #15051-0460) - (WES #607)
		➤ Plate Heat Exchanger

***Submittal Review Comments**

➔ **Contractor responsible for fitment when submitting equipment different than basis of design.**

c: Kelvin Patel
Kpatel@cannondesign.com

☐ Furnish as Submitted

☒ ***Furnish as Noted**

☐ Rejected

☐ Revise & Resubmit

☐ Reviewed

☐

Corrections or comments made on shop drawings during this review do not relieve contractor from compliance with requirements of drawings and specifications. This check is only for review of general conformance with the design concept of project and general compliance with information given in contract documents. Contractor is responsible for: confirming and correlating all quantities and dimensions; selecting fabrication processes and techniques of construction; coordinating his work with that of all other trades; and performing his work in a safe and satisfactory manner.

14127.01 - 235000 M13
MTN TO REVIEW
01/26/17

WTASHOP - Webster ISB - 23 5000-014

From: STL-CAC <STL-CAC@CANNONDESIGN.COM>
To: 'Patrick Garner' <pgarner@wmtao.com>, "WTASHOP (WTASHOP@wmtao.com)" <WTA...>
Date: 1/26/2017 5:17 PM
Subject: Webster ISB - 23 5000-014
Cc: "Patel, Kelvin" <kpatel@CANNONDESIGN.COM>
Attachments: 235000-014 Plate Heat Exchanger Product Data.pdf

Attached for review.

Melissa Pirtle

CANNONDESIGN

1100 Clark Ave
St. Louis, Missouri 63102
T [314.425.8797](tel:314.425.8797)
cannondesign.com

SUBMITTAL IDENTIFICATION SHEET

To be completed by Contractor/CM

PROJECT NAME	
ADDRESS	
NUMBER	
OWNER	
ARCHITECT / ENGINEER	
SUBMITTED BY	
CONTRACTOR / CM SUBMITTAL NO.	CANNON DESIGN SUBMITTAL NO.
DRAWING / DETAIL REFERENCE	SPECIFICATION SECTION / PARAGRAPH
MANUFACTURER / SUPPLIER	ITEM / PRODUCT ID
REQUIRED DATE	PRIORITY
CRITICALITY	

To be completed by Reviewer

CANNON DESIGN SUBMITTAL NUMBER
RECEIVED DATE

- ☐ **A. No Exceptions Taken**
No further review of submittal is required.
- ☐ **B. Make Corrections Noted**
Incorporate corrections in work;
resubmission is not required.
- ☐ **C. Revise and Resubmit**
Revise as noted, and resubmit for review.
- ☐ **D. Rejected**
Submittal is not in compliance with Contract Documents;
provide new submittal.
- ☐ **E. For Record / Information Only**
Submittal was reviewed for Record / Information
purposes only.
- ☐ **F. Not Required for Review**
Submittal is not required by Contract Documents
and has not been reviewed.

Review is for conformance with the design concept of this project and for general compliance with contract documents. Contractor is responsible for quantities, dimensions and compliance with contract documents and for information that pertains to fabrication processes, construction techniques and coordination of this work with all trades which will be affected thereby. This review is null and void if submittal deviates from contract documents and does not indicate or note deviations.

ITEM BEING SUBMITTED (check only one)

- ☐ Shop Drawings ☐ Certification / Qualifications ☐ Coordination Drawing
☐ Samples ☐ Record Documents ☐ Calculations
 (_____ copies) ☐ Product Data ☐ Schedules
☐ LEED Submittal ☐ O&M Manuals
☐ Other _____

ITEM BEING SUBMITTED FOR (check only one)

- ☐ Action ☐ Information Only ☐ Record

REMARKS OR DEVIATIONS

CONTRACTOR / CM CERTIFICATION
(SUBMITTALS NOT CERTIFIED WILL BE RETURNED WITHOUT REVIEW)



PARIC CORPORATION
SUBMITTAL STAMP

THIS SHOP DRAWING HAS BEEN REVIEWED BY PARIC CORPORATION

Subcontractor remains responsible for dimensions, quantities, coordination with other trades and compliance with contract documents.

Ry:

By:
Devin D. Gates

REVIEWED BY	DATE

A/E COMMENTS

- ☐
- See attached sheet(s) for additional comments

REVIEWED BY	DATE



77 Westport Plaza
Suite 250
St. Louis, MO 63146

TRANSMITTAL

No. 15051-0460

Paric Corporation

PROJECT: 15051-Webster University Interdisciplinary Science Building

DATE: 01/26/2017

TO: Cannon Design
1100 Clark Ave
St Louis MO 63102

Fax;
314-241-2203

RE: Plate Heat Exchanger Product Data

ATTN: Kelvin Patel

JOB: 15051

WE ARE SENDING:	SUBMITTED FOR:	ACTION TAKEN:
☐ Shop Drawings	☒ Approval	☐ Approved as Submitted
☐ Letter	☐ Your Use	☐ Approved as Noted
☐ Prints	☐ As Requested	☐ Returned After Loan
☐ Change Order	☐ Review and Comment	☐ Resubmit
☐ Plans		☐ Submit
☐ Samples	SENT VIA:	☐ Returned
☐ Specifications	☐ Attached	☐ Returned for Corrections
☒ Other: Product Data	☐ Separate Cover Via:	☐ Due Date:

Item	Package	Code	Rev.	Copies	Date	Description	Status
Submittal		235000-014	1		01/26/2017	Plate Heat Exchanger Product Data	Submitted

NOTES:

CC:

Signed: _____
Devin Gates



Mechanical

LETTER OF TRANSMITTAL

TO: Paric Corporation

77 West Port Plaza #250

St. Louis, MO 63146

ATTN: Jason Szachnieski, Devin Gates

DATE: 1/25/17

JOB #: 5768

RE: Webster ISB

We are sending you

☒

Shop drawings

☐ Attached

☐ Prints

☐ Under separate cover

☐ Plans

☐ Samples

☐ Specifications

☐ Copy of letter

☐ Change order

☐ Other

COPIES	DATE	NO.	DESCRIPTION
1	1/25/17	235000-2.16	Plate Heat Exchanger

These are transmitted as checked below:

☐ For signature

☐ For your use

☐ As requested

☐ For bids due

☒

For review and comment

☐ Approved as submitted

☐ Approved as noted

☐ Returned for corrections

☐ Prints returned after loan to us

☐ Other

☐ Resubmit

☒ Submit

☐ Return

☐ copies for approval

☐ copies for distribution

☐ corrected prints

Remarks: Please return by 2/1/17

COPY TO: file

SIGNED:

Alex Chambers



Mechanical

Webster University ISB Webster Groves, MO

Submittal #:

235000-2.16

Submittal Description:

Plate Heat Exchanger

Return By:

2/1/17

Please Note: To avoid scheduling delays and equipment release delays, please submit by the "Return By" date.

CHECKED BY:			
DESIGNER:		ENGINEER:	
☒	NO EXCEPTION TAKEN	☐	MAKE CORRECTIONS NOTED
☐	SUBMIT SPECIFIED ITEM	☐	REVISE AND RESUBMIT
☐	REJECTED	☐	
Checking is only for general conformance with the design concept of the project and general compliance with the information given in the contract documents. Any action shown is subject to the requirements of the plans and specifications. Equipment supplier is responsible for: dimensions which shall be confirmed and correlated at the job site; fabrication processes and techniques of construction; coordination of his work with that of all other trades; and satisfactory performance of his work.			
		Job #:	5768
		Date:	1/25/17
		By:	ARC