

600 Volts. Copper Conductor
Thermoplastic Insulation/ SIM Nylon Sheath
Heat, Moisture, Gasoline, and Oil Resistant II
Also Rated MTW and THWN-2
SIM Technology® for Easier Pulling



APPLICATIONS

Southwire SIMpull THHN or THWN-2 conductors are primarily used in conduit and cable trays for services, feeders, and branch circuits in commercial or industrial applications as specified in the National Electrical Code. Voltage for all applications is 600 volts. SIMpull THHN conductors are designed to be used without application of pulling lubricant. Allowable temperatures are as follows:

- THHN or T90 Nylon- Dry locations not to exceed 90° C
- THWN-2- Wet or dry locations not to exceed 90° C or locations not to exceed 75° C when exposed to oil
- TWN75- Wet locations not to exceed 75° C
- MTW- Wet locations or when exposed to oil at temperatures not to exceed 60° C or dry locations not to exceed 90° C (with ampacity limited to that for 75° C conductor temperature per NFPA 79)
- AWM- Dry locations not to exceed 105° C when rated and used as appliance wiring material

SPECIFICATIONS

Southwire SIMpull THHN ® or THWN-2 or MTW (also AWM) comply with:

- ASTM - All applicable standards
- UL Standard 83, 1581, and 1063(MTW)
- T90 Nylon/TWN75 sizes through 1000 kcmil CSA C22.2 No. 75
- NOM-ANCE 90° C
- Federal Specification A-A-59544
- National Electrical Code, NFPA 70
- VW-1 - Sizes 14 through 1 AWG
- CT rated in sizes 1/0 AWG and larger
- FT1
- AWM - Sizes 14 through 6 AWG. MTW available in stranded only
- NEMA WC-70 Construction Requirements
- RoHS/REACH Compliant

Construction

Southwire SIMpull THHN or THWN-2 or MTW copper conductors are soft annealed copper. #14 - 4/0 AWG uses a combination unilay strand and 250 kcmil and larger uses a compressed copper strand. The wire is insulated with a tough heat and moisture resistant poly vinyl chloride (PVC), over which a SIM (SLIKQWIK® Infused Membrane) nylon (polyamide) or UL Recognized equal jacket is applied. Available in black, white, red, blue, purple, green, yellow, orange, brown and gray. Some colors are subject to economic order quantity. Marked sunlight resistant in sizes 2 AWG and larger.

THWN-2 available in sizes 8 AWG and larger .

Sizes 14 - 10 AWG are available with SIMpull Technology only in SIMpull Barrel configurations.



Southwire
One Southwire Drive
Carrollton, Ga. 30119 USA



NoLube™

Copyright 2012 Southwire Company. All Rights Reserved
Southwire is a registered trademark of Southwire Company

SIMPull THHN

Conductor		Insulation Thickness (mils)	Jacket Thickness (mils)	Nominal O.D. (mils)	Approx. Weight per 1000' (lbs)	Allowable Ampacities+			Standard Package
Size (AWG or kcmil)	Number of Strands					60° C	75° C	90° C	
14*	1	15	4	102	15	15	15	15	AC
12*	1	15	4	119	23	20	20	20	AC
10*	1	20	4	150	36	30	30	30	AC
14*	19	15	4	109	16	15	15	15	AC
12*	19	15	4	128	24	20	20	20	AC
10*	19	20	4	161	38	30	30	30	AC
8	19	30	5	213	63	40	50	55	ABCD
6	19	30	5	249	95	55	65	75	ABCD
4	19	40	6	318	152	70	85	100	ABCD
3	19	40	6	346	189	85	100	115	ABCD
2	19	40	6	378	234	95	115	130	ABCD
1	19	50	7	435	299	110	130	145	ABCD
1/0	19	50	7	474	372	125	150	170	ABCD
2/0	19	50	7	518	462	145	175	195	ABCD
3/0	19	50	7	568	575	165	200	225	ABCD
4/0	19	50	7	624	718	195	230	260	ABCD
250	37	60	8	694	851	215	255	290	ABCD
300	37	60	8	747	1012	240	285	320	ABC
350	37	60	8	797	1174	260	310	350	ABC
400	37	60	8	842	1334	280	335	380	ABC
500	37	60	8	926	1655	320	380	430	ABCD
600	61	70	9	1024	1987	350	420	475	ABC
750	61	70	9	1126	2464	400	475	535	BC
1000	61	70	9	1275	3257	455	545	615	C
* Sizes 14 - 10 AWG available with patented Sim Technology® No Lube® jacket only in SIMpull® Wire Barrel configurations. +Allowable ampacities shown are for general use as specified by the 2011 Edition of the National Electrical Code Section 310.15 and 240.4(D). Unless the equipment is marked for use at higher temperatures the conductor shall be limited to the following per NEC 110.14(C). 60° C - When terminated to equipment for circuits rated 100 amperes or less or marked for 14 - 1 AWG conductors. 75° C - When terminated to equipment for circuits rated over 100 amperes or marked for conductors larger than 1 AWG. 90° C - THHN dry locations and THWN wet or dry locations for ampacity adjustment purposes using NEC section 310.15.								Standard Package: A - 2500' Reel B - 1000' Reel C - 500' Spool D - 5000' Reel	

Shop Drawing Submittal Review

Transmitted To: Cannon Design

Date: August 8, 2016

Attention: stl-cac@cannondesign.com

Contact Person / WTA Field Inspector:
Patrick Garner

Project Name: Webster University-**ISB**

Reviewed by: Bill Shaw

Project No. WT 14127.01

☐

UPS

☐

Courier

☒

Email

Copies	No.	Description
1 PDF	261200E01	(Submittal No.'s) (R&B CxSRC - None)
		(Cannon #261200-003) - (Paric #15051-) - (WES #607)
		• Wiring 600 Volts or Less

Remarks:

c: **Kelvin Patel**
Kpatel@cannondesign.com

☒ **Furnish as Submitted**

☐ Furnish as Noted

☐ Rejected

☐ Revise & Resubmit

☐ Reviewed

☐

Corrections or comments made on shop drawings during this review do not relieve contractor from compliance with requirements of drawings and specifications. This check is only for review of general conformance with the design concept of project and general compliance with information given in contract documents. Contractor is responsible for: confirming and correlating all quantities and dimensions; selecting fabrication processes and techniques of construction; coordinating his work with that of all other trades; and performing his work in a safe and satisfactory manner.

WTASHOP - Webster ISB - 26 1200-003

From: STL-CAC <STL-CAC@CANNONDESIGN.COM>
To: 'Patrick Garner' <pgarner@wmtao.com>, WTASHOP <wtashop@wmtao.com>
Date: 8/2/2016 2:48 PM
Subject: Webster ISB - 26 1200-003
Cc: "Patel, Kelvin" <kpatel@CANNONDESIGN.COM>
Attachments: 261200-003 Wiring 600V or Less Product Data.pdf

Attached for review.

Melissa Pirtle
Construction Admin

CANNONDESIGN

1100 Clark Ave
St. Louis, Missouri 63102
T [314.425.8797](tel:314.425.8797) • M
cannondesign.com

SUBMITTAL IDENTIFICATION SHEET

To be completed by Contractor/CM

PROJECT NAME	
ADDRESS	
NUMBER	
OWNER	
ARCHITECT / ENGINEER	
SUBMITTED BY	
CONTRACTOR / CM SUBMITTAL NO.	CANNON DESIGN SUBMITTAL NO.
DRAWING / DETAIL REFERENCE	SPECIFICATION SECTION / PARAGRAPH
MANUFACTURER / SUPPLIER	ITEM / PRODUCT ID
REQUIRED DATE	PRIORITY
CRITICALITY	

To be completed by Reviewer

CANNON DESIGN SUBMITTAL NUMBER
RECEIVED DATE

- ☐ **A. No Exceptions Taken**
No further review of submittal is required.
- ☐ **B. Make Corrections Noted**
Incorporate corrections in work;
resubmission is not required.
- ☐ **C. Revise and Resubmit**
Revise as noted, and resubmit for review.
- ☐ **D. Rejected**
Submittal is not in compliance with Contract Documents;
provide new submittal.
- ☐ **E. For Record / Information Only**
Submittal was reviewed for Record / Information
purposes only.
- ☐ **F. Not Required for Review**
Submittal is not required by Contract Documents
and has not been reviewed.

Review is for conformance with the design concept of this project and for general compliance with contract documents. Contractor is responsible for quantities, dimensions and compliance with contract documents and for information that pertains to fabrication processes, construction techniques and coordination of this work with all trades which will be affected thereby. This review is null and void if submittal deviates from contract documents and does not indicate or note deviations.

ITEM BEING SUBMITTED (check only one)

- ☐ Shop Drawings ☐ Certification / Qualifications ☐ Coordination Drawing
☐ Samples ☐ Record Documents ☐ Calculations
 (_____ copies) ☐ Product Data ☐ Schedules
☐ LEED Submittal ☐ O&M Manuals
☐ Other _____

ITEM BEING SUBMITTED FOR (check only one)

- ☐ Action ☐ Information Only ☐ Record

REMARKS OR DEVIATIONS

CONTRACTOR / CM CERTIFICATION
(SUBMITTALS NOT CERTIFIED WILL BE RETURNED WITHOUT REVIEW)

PARIC CORPORATION
SUBMITTAL STAMP

THIS SHOP DRAWING HAS BEEN REVIEWED BY PARIC CORPORATION

Subcontractor remains responsible for dimensions, quantities, coordination with other trades and compliance with contract documents.

Ry:

Devin D. Gates

REVIEWED BY	DATE

A/E COMMENTS

- ☐
- See attached sheet(s) for additional comments

REVIEWED BY	DATE



77 Westport Plaza
Suite 250
St. Louis, MO 63146

TRANSMITTAL

No. 15051-0167

Paric Corporation

PROJECT: 15051-Webster University Interdisciplinary Science Building

DATE: 08/02/2016

TO: Cannon Design
1100 Clark Ave
St Louis MO 63102

RE: Wiring 600V or Less Product Data

ATTN: Kelvin Patel

JOB: 15051

WE ARE SENDING:		SUBMITTED FOR:	ACTION TAKEN:
☐ Shop Drawings		☒ Approval	☐ Approved as Submitted
☐ Letter		☐ Your Use	☐ Approved as Noted
☐ Prints		☐ As Requested	☐ Returned After Loan
☐ Change Order		☐ Review and Comment	☐ Resubmit
☐ Plans			☐ Submit
☐ Samples		SENT VIA:	☐ Returned
☐ Specifications		☐ Attached	☐ Returned for Corrections
☒ Other: Product Data		☐ Separate Cover Via:	☐ Due Date:

Item	Package	Code	Rev.	Copies	Date	Description	Status
Submittal		261200-003	1		08/02/2016	Wiring 600V or Less Product Data	Submitted

NOTES:

CC:

Signed: _____
Devin Gates

Transmittal

To Paric Corporation

Date 8/1/16

Job Number 11317

Job Name Webster Univ. ISB Building

Attention Devin Gates Transmittal Number 11317-013

We are sending you:

☒ Attached

☐ Under separate cover, the following:

☐ Preliminary Drawings

☐ Samples

☐ Construction Drawings

☐ Copy of Letter

☐ Specifications

☐ Other _____

Quantity	Drawing #	Date/Revision	Description
1			Submittal for Wire 600V or Less - Spec
			Section 26 12 00

These are transmitted as checked:

☒ For Your Review & Comment

☐ Approved As Noted

☒ For Approval

☐ Returned For Corrections

☐ For Your File

☐ Approved As Submitted

☐ As Requested

☐

Copy:

Transmittal

Enclosure

Rick Branstetter

Signed: Rick Branstetter, Project Manager