


REV	DESCRIPTION	BY	DATE	—	----	---	---/---/---
1	UPDATED PRINT	AMS	12/7/16	—	----	---	---/---/---

CKT NO	ACCESSORIES	TYPE	RATING AMP/P	S/N	225A M/L	A	B	C	S/N	RATING AMP/P	TYPE	ACCESSORIES	CKT NO
1		EGB	20/1							20/1	EGB		2
3		EGB	20/1							20/1	EGB		4
5		EGB	20/1							20/1	EGB		6
7		EGB	20/1							20/1	EGB		8
9		EGB	20/1							20/1	EGB		10
11		EGB	20/1							20/1	EGB		12
13		EGB	20/1							20/1	EGB		14
15		EGB	20/1							20/1	EGB		16
17		EGB	20/1							20/1	EGB		18
19		EGB	20/1							20/1	EGB		20
21		EGB	20/1							20/1	EGB		22
23		EGB	20/1							20/1	EGB		24
25		EGB	20/1							20/1	EGB		26
27		EGB	20/1							20/1	EGB	PREPARED SPACE	28
29	PREPARED SPACE	EGB	20/1							20/1	EGB	PREPARED SPACE	30
31	PREPARED SPACE	EGB	20/1							20/1	EGB	PREPARED SPACE	32
33	PREPARED SPACE	EGB	20/1							20/1	EGB	PREPARED SPACE	34
35	PREPARED SPACE	EGB	20/1							20/1	EGB	PREPARED SPACE	36
37		EGB	20/1							20/1	EGB	PREPARED SPACE	38
39	XFRM PRIMARY	EGB	45/3							20/1	EGB	PREPARED SPACE	40
41										20/1	EGB	PREPARED SPACE	42

37999262-FM1

SEISMIC QUALIFIED LABEL REQUIRED



PHYSICAL DATA

- ENCLOSURE: INTERIOR ONLY

FRONT CAT#: N/A

BOX CAT#: N/A

DIMENSIONS:

"H X "W X "D

WIRE BENDING SPACE:

TOP

BOTTOM

SIDE

PBA 507A

- BUSSING: COPPER BUS
STANDARD PLATING

- SPECIAL:
SPD SURGE SUPPRESSION
PEAK SURGE RATING: 100kA
WITH DRY CONTACTS
WITH SURGE COUNTER
STANDARD SOLID NEUTRAL
STANDARD GROUND BAR

ELECTRICAL DATA

- SYSTEM: 480Y/277 VAC 3PH 4W 60 HZ
35,000 AMPS SYMS.

- MAIN LUGS: 225A
ACC:
TOP FEED

- BRANCH MOUNTING TYPE: BOLT-ON

JOB NAME:	WEBSTER UNIVERSITY ISB	EQUIPMENT DESIGNATION:	PANEL 1EH1
JOB LOCATION:	WEBSTER GROVES, MO	EQUIPMENT TYPE:	NF
DRAWN BY:	AMS	DRAWING TYPE:	IPC2
ENGR:	AMS		
DATE:	10/3/2016		
DRAWING STATUS:	RECORD	DWG# 37999262-007-1-01-1	PG 1 OF 4 REV -

